

# STATE OF COLORADO

John W. Hickenlooper, Governor  
Larry Wolk, MD, MSPH  
Executive Director and Chief Medical Officer

Dedicated to protecting and improving the health and environment of the people of Colorado

4300 Cherry Creek Dr. S.  
Denver, Colorado 80246-1530  
Phone (303) 692-2000  
Located in Glendale, Colorado  
[www.colorado.gov/cdphe](http://www.colorado.gov/cdphe)



Colorado Department  
of Public Health  
and Environment

January 17, 2014

Meadow Mountain Water Supply Compay  
Rachel Barkworth, Administrative Contact  
P.O. Box 354  
Allenspark, CO 80510

Re: Implementation/Compliance Schedule for Enforcement Order DC-110829-1  
Meadow Mountain WSC—PWSID # CO0207524

Ms. Barkworth:

The Water Quality Control Division (the "Division") has received Meadow Mountain WSC's Preliminary Engineering Report dated December 2013 from Lidstone and Associates, Inc. The report outlines a selected alternative including reusing the existing sedimentation facilities, installing new 20 micron pre-filters, and installing a new Innovative Water Technologies ultrafiltration system. The Division's Engineering Staff has reviewed the PER and has determined that the project is capable of meeting both the filtration and disinfection requirements of the CPDWRs.

On January 15, 2014, the Division participated in a conference call that included you, Kari Sholtes, Marty Jones and Ryan Duve from Lidstone and Associates, Jack Barker from IWT, and Tyson Ingels, Emily Becker, Amy Zimmerman and me from CDPHE; we discussed your request for an extension to the implementation schedule required in paragraph 21(b) of the Enforcement Order. Based on our discussion, the Division has approved the schedule listed below and will determine compliance with the Enforcement Order at paragraph 21(b) based on the revised schedule as follows:

- By February 20, 2014: Submit Final Design Plans and Specifications to the Division
- Upon approval of Final Design Plans and Specifications: Begin Construction
- Within 200 days of Beginning Construction: Complete Construction

Within ten (10) days of completion of construction, please submit a Certificate of Construction Completion form to the Division.

If you have any questions, please contact me at 303-692-3254 or by electronic mail at [robert.pohl@state.co.us](mailto:robert.pohl@state.co.us).

Sincerely,

A handwritten signature in black ink that reads "Robert Pohl". The signature is written in a cursive style with a large, stylized 'R' and 'P'.

Robert Pohl  
Drinking Water Compliance Specialist  
Compliance Assurance Monitoring and Enforcement Unit  
Water Quality Control Division - CDPHE

cc: Drinking Water Enforcement File  
ec: Amy Zimmerman, PE, Engineering Design Review North Unit Manager, CDPHE  
Nicole Graziano, Compliance and Enforcement North Unit Manager, CDPHE