



Colorado Department
of Public Health
and Environment

Colorado Department of Public Health and Environment Compliance Assurance & Data Management Unit

REPORTING FORM FOR INORGANIC CONTAMINANTS ANALYSES

SAMPLER: FILL OUT ONE FORM FOR EACH SAMPLE

Are these results to be used to fulfill compliance monitoring requirements? YES ☒ or NO ☐

Is this a check or confirmation sample? ☐ YES ☒ NO

PWSID CO0207504 COUNTY: Boulder DATE COLLECTED: 04/15/07

SYSTEMS NAME: Meadow Mountain Water Company

SYSTEM MAILING ADDRESS: P.O. Box 162 Allenspark CO 80510
Street address- PO Box CITY STATE ZIP

CONTACT PERSON: Steve Tedford PHONE: (303) 747-2066

SAMPLE COLLECTED BY: Steve Tedford TIME COLLECTED: 7:10 pm am/pm

ENTRY POINT (Finished Water) SAMPLE ☒ SOURCE WATER SAMPLE ☐

FOR ENTRY POINT SAMPLE PLEASE INDICATE: Chlorinated ☒ Other Treatment ☐
Finished—Not Treated (No chlorine or other treatment) ☐

STATE ENTRY POINT CODE: EP Distribution SOURCE(S) REPRESENTED: Surface Water

DO SAMPLES NEED TO BE COMPOSITED BY THE LABORATORY? YES ☐ NO ☒

NOTE: CHECK OR CONFIRMATION SAMPLES CANNOT BE COMPOSITED

For Laboratory Use Only Below This Line

LABORATORY SAMPLE # 702169 CLIENT NAME or ID# Meadow Mountain Water Company (1115-017)

LABORATORY NAME Stewart Environmental Consultants, Inc.

LAB PHONE #: (970) 226-5500 DATE RECEIVED IN LABORATORY 04/16/07

COMMENTS:

PARAMETER	RESULT in (mg/L)	MCL in (mg/L)	STANDARD METHOD	Lab MDL in (mg/L)	Date Analyzed
Antimony	BDL	0.006	200.9	0.005	04/30/07
Arsenic	BDL	0.05/0.010*	200.9	0.005	05/03/07
Barium	0.003	2.0	200.7	0.001	04/19/07
Beryllium	BDL	0.004	200.7	0.0001	04/19/07
Cadmium	BDL	0.005	200.9	0.001	04/30/07
Chromium	BDL	0.1	200.7	0.01	04/19/07
Cyanide	NT	0.2	4500CN-C-E		
Fluoride	BDL	4.0	4500F-C	0.5	04/18/07
Mercury	BDL	0.002	245.1	0.0001	05/09/07
Nickel	BDL	**	200.7	0.01	04/19/07
Selenium	BDL	0.05	200.9	0.005	04/17/07
Sodium	3.3	**	200.7	0.01	04/19/07
Thallium	BDL	0.002	200.9	0.002	05/08/07

* 0.010 mg/L is effective January 2006

** Monitoring is required, but there is no MCL for this contaminant

RM. Slavovick Laboratory Manager
Reviewed & Approved by Title

06 / 01 / 07
Date

MAIL RESULTS TO: CDPHE, WQCD-CADM
4300 Cherry Creek Drive South
Denver, CO 80246-1530

FAX: 303-782-0390