

Client Name: Meadow Mountain Water Company
Project Number: 1115-017
Sample Name: # 1
Sample Matrix: Water
Sample Number: 705367
Sample Date: 09/06/07
Date Received: 09/06/07
Analysts: WVS

FA807
10-7-07

PARAMETER	TESTED VALUE	DETECT LIMIT	METHOD NUMBER	DATE OF ANALYSIS
METALS				
Copper	0.012	0.010	200.7/1	09/12/07
Lead/GF	ND	0.005	200.9/1	09/07/07

Values are reported in parts per million (ppm) unless otherwise noted.

ND = Not Detected

1. Methods for Chemical Analysis of Water and Wastes, March 1993, EPA

Client Name: Meadow Mountain Water Company
Project Number: 1115-017
Sample Name: # 2
Sample Matrix: Water
Sample Number: 705368
Sample Date: 09/06/07
Date Received: 09/06/07
Analysts: WVS

PARAMETER	TESTED VALUE	DETECT LIMIT	METHOD NUMBER	DATE OF ANALYSIS
METALS				
Copper	0.137	0.010	200.7/1	09/12/07
Lead/GF	ND	0.005	200.9/1	09/07/07

Values are reported in parts per million (ppm) unless otherwise noted.

ND = Not Detected

1 Methods for Chemical Analysis of Water and Wastes, March 1993, EPA

Client Name: Meadow Mountain Water Company
Project Number: 1115-017
Sample Name: # 3
Sample Matrix: Water
Sample Number: 705369
Sample Date: 09/06/07
Date Received: 09/06/07
Analysts: WVS

PARAMETER	TESTED VALUE	DETECT LIMIT	METHOD NUMBER	DATE OF ANALYSIS
METALS				
Copper	0.065	0.010	200.7/1	09/12/07
Lead/GF	ND	0.005	200.9/1	09/07/07

Values are reported in parts per million (ppm) unless otherwise noted.

ND = Not Detected

1 Methods for Chemical Analysis of Water and Wastes, March 1993, EPA

Client Name: Meadow Mountain Water Company
Project Number: 1115-017
Sample Name: # 4
Sample Matrix: Water
Sample Number: 705370
Sample Date: 09/06/07
Date Received: 09/06/07
Analysts: WVS

PARAMETER	TESTED VALUE	DETECT LIMIT	METHOD NUMBER	DATE OF ANALYSIS
METALS				
Copper	0.254	0.010	200.7/1	09/12/07
Lead/GF	0.011	0.005	200.9/1	09/07/07

Values are reported in parts per million (ppm) unless otherwise noted.
1 Methods for Chemical Analysis of Water and Wastes, March 1993, EPA

Client Name: Meadow Mountain Water Company
Project Number: 1115-017
Sample Name: # 5
Sample Matrix: Water
Sample Number: 705371
Sample Date: 09/06/07
Date Received: 09/06/07
Analysts: WVS

PARAMETER	TESTED VALUE	DETECT LIMIT	METHOD NUMBER	DATE OF ANALYSIS
METALS				
Copper	0.153	0.010	200.7/1	09/12/07
Lead/GF	ND	0.005	200.9/1	09/07/07

Values are reported in parts per million (ppm) unless otherwise noted.

ND = Not Detected

1 Methods for Chemical Analysis of Water and Wastes, March 1993, EPA