

JANUARY 2008

MONTHLY OPERATIONAL REPORT - Data Sheet
SLOW SAND, DIATOMACEOUS EARTH & OTHER FILTRATION

Meadow Mountain WS

Required Number of Turbidity Readings Per Day: 1

PWSID #: 01-0207504

DAY	TURBIDITY (NTU)								RESIDUAL DISINFECTANT (mg/L)								12. COMMENTS
	☐ Continuous Sampling ☒ Grab Sampling						HIGHEST TURBIDITY READING	TIME TURBIDITY READ	☐ Continuous Sampling ☒ Grab Sampling						LOWEST RESIDUAL READING		
	12 to 4	4 to 8	8 to 12	12 to 4	4 to 8	8 to 12			ENTRY POINT TO DISTRIBUTION								
1			21				21	9:30A				.9				.9	
2				20			20	2:00P				.9				.9	
3		.75					.75	7:30A		.8						.8	
4				32			32	1:45P				.8				.8	
5			.20				.20	10:30A				.9				.9	
6			.27				.27	11:20A				.9				.9	
7			.37				.37	11:13A				.9				.9	
8						.32	.32	9:00P						.9		.9	
9			.75				.75	5:15A		.9						.9	
10			.48				.48	11:15A		1.0						1.0	
11				.42			.42	3:30P				.9				.9	
12				.46			.46	3:00P				.9				.9	
13						.26	.26	8:50P						.5		.5	
14						.32	.32	6:05P						.5		.8	
15			.42				.42	11:30A		.9						.9	
16				.23			.23	2:00P				.9				.9	
17			.75				.75	3:45P				.9				.9	
18				.36			.36	3:50P				1.0				1.0	
19			.65				.65	2:10P				1.1				1.1	
20						.52	.52	9:20P						1.0		1.0	
21					.48		.48	4:15P						1.0		1.0	
22				.40			.40	2:00P				.9				.9	
23				.35			.35	3:00P				.9				.9	
24					.22		.22	4:20P						.9		.9	
25					.36		.36	4:10P						1.0		1.0	
26					.32		.32	4:05P						.9		.9	
27			.35				.35	11:30P		.8						.8	
28					.33		.33	5:00P						1.0		1.0	
29		.32					.32	7:30P		.9						.9	
30			.40				.40	10:00A			1.0					1.0	
31				.42			.42	3:45				.9				.9	

If at Any Time the combined filter effluent turbidity exceeds 5 NTU (>5.49), the state must be notified as soon as possible, but not later than the end of the next business day.