

February 2008

MONTHLY OPERATIONAL REPORT - Data Sheet
SLOW SAND, DIATOMACEOUS EARTH & OTHER FILTRATION

Meadow-Mt WS

Required Number of Turbidity Readings Per Day: 1

PWSID #: 00-0207504

DAY	TURBIDITY (NTU)								RESIDUAL DISINFECTANT (mg/L)								12. COMMENTS
	☐ Continuous Sampling ☒ Grab Sampling						HIGHEST TURBIDITY READING	TIME TURBIDITY READ	☐ Continuous Sampling ☒ Grab Sampling						LOWEST RESIDUAL READING		
	12 to 4	4 to 8	8 to 12	12 to 4	4 to 8	8 to 12			12 to 4	4 to 8	8 to 12	12 to 4	4 to 8	8 to 12			
1			.29				.29	11:45A				1.0			1.0		
2					.32		.32	7:30P				.9			.9		
3			.28				.28	8:15A				.9			.9		
4			.70				.30	8:05P				.9			.9		
5					.38		.38	4:30P				.9			.9		
6		.42					.42	6:40P		.9					.9		
7			.29				.29	11:00A			1.0				1.0		
8					.36		.36	4:30P				.9			.9		
9			.38				.38	10:45A			.9				.9		
10			.26				.26	11:45A			.9				.9		
11					.43		.43	5:00P				1.0			1.0		
12					.19		.19	5:30P				1.1			1.1		
13					.53		.53	5:00P				1.0			1.0		
14				.31			.31	3:30P			1.0				1.0		
15			.34				.34	10:30P		.9					.9		
16					.34		.34	5:40P			.9	.4			.9		
17					.72		.32	6:05P				.9			.9		
18					.36		.36	7:45P				.9			.9		
19				.38			.38	1:30P			.9				.9		
20			.47				.47	11:45A		.9					.9		
21				.28			.28	2:00P			1.0				1.0		
22			.28				.28	11:15A		1.0					1.0		
23					.28		.28	4:00P				1.0			1.0		
24				.20			.20	1:10P			1.0				1.0		
25		.43					.43	8:20A		1.1					1.1		
26				.35			.35	4:00P			1.0				1.0		
27					.31		.31	11:30P				.9			.9		
28				.30			.30	1:30P			1.0				1.0		
29				.26			.26	3:45P			1.0				1.0		
30																	
31																	

If at Any Time the combined filter effluent turbidity exceeds 5 NTU (>5.49), the state must be notified as soon as possible, but not later than the end of the next business day.