

March
2008

STATE OF CALIFORNIA DEPARTMENT OF PUBLIC HEALTH AND ENVIRONMENT
MONTHLY OPERATIONAL REPORT - Data Sheet
SLOW SAND, DIATOMACEOUS EARTH & OTHER FILTRATION

Required Number of Turbidity Readings Per Day: 1

PWSID #: CA-0207504

DAY	TURBIDITY (NTU)						RESIDUAL DISINFECTANT (mg/L)								12. COMMENTS	
	☐ Continuous Sampling			☒ Grab Sampling			☐ Continuous Sampling				☒ Grab Sampling					
	12 to 4	4 to 8	8 to 12	12 to 4	4 to 8	8 to 12	HIGHEST TURBIDITY READING	TIME TURBIDITY READ	ENTRY POINT TO DISTRIBUTION							LOWEST RESIDUAL READING
									12 to 4	4 to 8	8 to 12	12 to 4	4 to 8	8 to 12		
1			.24				.24	11:00P			1.0				1.0	
2				.26			.26	2:30P				1.0			1.0	
3			.26				.28	3:05P				.9			.9	
4						.20	.20	9:30P						.7	.7	
5					.26		.26	4:30P					.8		.8	
6			.30				.30	2:20P				1.0			1.0	
7			.28				.28	10:30A			1.0				1.0	
8				.26			.26	2:30P				.9			.9	
9				.30			.30	2:40P				.9			.9	
10					.26		.26	5:15P					.9		.9	
11				.39			.39	2:00P			1.0				1.0	
12						.36	.36	9:45P						.9	.9	
13				.31			.31	3:30P			1.0				1.0	
14					.23		.23	4:30P					1.0		1.0	
15				.26			.26	2:30P				.9			.9	
16					.25		.25	5:30P				1.0			1.0	
17					.31		.31	5:00P				1.0			1.0	
18					.27		.27	4:45P					.9		.9	
19			.26				.26	8:15P			.9				.9	
20			.24				.24	11:45A			.9				.9	
21		.26					.26	7:15P		.9					.9	
22			.26				.26	11:30P			.9				.9	
23				.22			.22	3:00P				.9			.9	
24			.25				.25	11:30A			1.0				1.0	
25			.23				.23	9:15A			.9				.9	
26				.24			.24	2:10P			1.0				1.0	
27					.24		.24	7:45P					.9		.9	
28			.28				.26	9:20A			.9				.9	
29			.30				.30	9:00A			1.0				1.0	
30				.19			.19	1:30P			1.0				1.0	
31					.46		.46	7:00P					1.0		1.0	

If at Any Time the combined filter effluent turbidity exceeds 5 NTU (>5.49), the state must be notified as soon as possible, but not later than the end of the next business day.