

Plaza 08
April

MONTHLY OPERATIONAL REPORT - Data Sheet
SLOW SAND, DIATOMACEOUS EARTH & OTHER FILTRATION

Required Number of Turbidity Readings Per Day: 1

PWSID #: *00-0207504*

DAY	TURBIDITY (NTU)							RESIDUAL DISINFECTANT (mg/L)							12. COMMENTS		
	☐ Continuous Sampling ☒ Grab Sampling						HIGHEST TURBIDITY READING	TIME TURBIDITY READ	☐ Continuous Sampling ☒ Grab Sampling							LOWEST RESIDUAL READING	
	12 to 4	4 to 8	8 to 12	12 to 4	4 to 8	8 to 12			ENTRY POINT TO DISTRIBUTION								
										12 to 4	4 to 8	8 to 12	12 to 4	4 to 8	8 to 12		
1				.31			.31	2:30P					.9			.9	
2				.34			.34	2:30P					1.0			1.0	
3			.36				.36	4:30P				.9				.9	
4			.34				.34	11:00P				.9				.9	
5			.32				.32	10:45P				.9				.9	
6				.23			.23	12:40P					1.0			1.0	
7					.42		.42	5:00P						1.0		1.0	
8				.35			.35	12:15P					.9			.9	
9					.32		.32	6:45P						.9		.9	
10					.46		.46	4:30P						.9		.9	
11					.38		.38	4:00P						1.1		1.1	
12					.32		.32	4:30P						.9		.9	
13			.35				.35	11:00A				.9				.9	
14			.31				.31	10:30A				.9				.9	
15					.33		.33	4:30P						1.0		1.0	
16					.28		.28	5:00P						1.0		1.0	
17			.74				.74	12:30P					.9			.9	
18			.45				.45	2:30P				1.0				1.0	
19					.46		.46	4:30P						1.0		1.0	
20			.38				.38	11:30A				1.0				1.0	
21			.73				.73	10:45A				1.0				1.0	
22				.57			.57	12:10P					1.0			1.0	
23			.85				.85	11:45A				1.1	1			1.1	
24					.73		.73	4:00P						1.0		1.0	
25					.83		.83	4:00P						1.0		1.0	
26				.91			.91	2:30P					.8			.8	
27			.74				.74	11:45				.9				.9	
28			.79				.79	10:30A				1.0				1.0	
29				.60			.60	3:30P					1.0			1.0	
30				.92			.92	1:30P						1.0		1.0	
31																	

If at Any Time the combined filter effluent turbidity exceeds 5 NTU (>5.49), the state must be notified as soon as possible, but not later than the end of the next business day.