

May 08

MONTHLY OPERATIONAL REPORT - Data Sheet

SLOW SAND, DIATOMACEOUS EARTH & OTHER FILTRATION

Required Number of Turbidity Readings Per Day: PWSID #: 10-0207504

DAY	TURBIDITY (NTU)								RESIDUAL DISINFECTANT (mg/L)								12. COMMENTS
	☐ Continuous Sampling ☒ Grab Sampling						HIGHEST TURBIDITY READING	TIME TURBIDITY READ	☐ Continuous Sampling ☒ Grab Sampling						LOWEST RESIDUAL READING		
	12 to 4	4 to 8	8 to 12	12 to 4	4 to 8	8 to 12			ENTRY POINT TO DISTRIBUTION								
										12 to 4	4 to 8	8 to 12	12 to 4	4 to 8	8 to 12		
1				.69			.69	2:30 P					.8				
2			.90				.90	10:30 A			.9						
3					.8		.80	4:30 P					1.0				
4				.70			.70	3:45 P				1.0					
5					.75		.75	7:45 P					.9				
6		.50					.50	7:15 P		.9							
7					.95		.95	4:45 P					.9				
8					.82		.82	4:00 P					.8				
9					.90		.90	4:30 P					.9				
10					.50		.50	5:15 P					.9				
11				.90			.90	1:00 P				.9					
12			.98				.98	11:00 A			.9						
13				.97			.97	12:45 P				.8					
14				.95			.95	3:00 P				.8					
15					.90		.90	5:30 P			.8		.8				
16			.90				.90	10:45 A			.8						
17				.91			.91	3:50 P				1.0					
18			.83				.83	10:50 A			1.0						
19					1.57		1.57	5:15 P					.9				
20					2.20		2.20	5:00 P					.7				
21			2.31				2.31	11:45 A			1.1						
22			1.89				1.89	11:30 A			1.2						
23					1.52		1.52	6:30 P					1.8				
24			1.48				1.48	8:00 A			1.0						
25			1.52				1.52	11:20 A			1.0						
26				1.47			1.47	12:30 P				1.0					
27					1.42		1.42	5:30 P					.9				
28			.93				.93	10:00 A			.8						
29			.81				.81	11:30 A			1.1						
30			.71				.71	3:30 P				1.0					
31				.79			.79	1:00 P				1.1					

If at Any Time the combined filter effluent turbidity exceeds 5 NTU (>5.49), the state must be notified as soon as possible, but not later than the end of the next business day.