

Aug. Meadow Mountain ^{WS}

MONTHLY OPERATIONAL REPORT - Data Sheet

FAXED 9-3-08

SLOW SAND, DIATOMACEOUS EARTH & OTHER FILTRATION

Required Number of Turbidity Readings Per Day: 1

PWSID #: 01-0207504

DAY	TURBIDITY (NTU)								RESIDUAL DISINFECTANT (mg/L)								12. COMMENTS
	☐ Continuous Sampling ☒ Grab Sampling						HIGHEST TURBIDITY READING	TIME TURBIDITY READ	☐ Continuous Sampling ☒ Grab Sampling						LOWEST RESIDUAL READING		
	12 to 4	4 to 8	8 to 12	12 to 4	4 to 8	8 to 12			ENTRY POINT TO DISTRIBUTION								
										12 to 4	4 to 8	8 to 2	12 to 4	4 to 8	8 to 12		
1		.38					.38	7:30A		.9						.9	
2				.28			.28	3:20		.5						.5	
3				.26			.26	12:45		.7						.7	
4			.28				.28	11:00A			.6					.6	
5			.37				.37	11:30A			.5					.5	
6				.39			.39	3:15P			.5					.5	
7					.35		.35	4:50P					1.1			1.1	
8				.46			.46	3:40P			.5					.5	
9				.65			.65	1:30P			.8					.8	
10					.46		.46	6:00P					.2			.2	
11			.30				.30	9:50A			.4					.4	
12				.35			.35	3:00P			.4					.4	
13					.32		.32	4:45P					.4			.4	
14			.43				.43	11:30A			1.2					1.2	
15				.26			.26	2:30P			.7					.7	
16				.22			.22	3:45P			.4					.4	
17			.62				.62	11:30A			.5					.5	
18			.40				.40	11:30A			.4					.4	
19				.42			.42	2:30P			.3					.3	
20				.52			.52	3:30P			.4					.4	
21					.50		.50	4:00P					.4			.4	
22				.61			.61	3:30P			.8					.8	
23				.54			.54	2:30P			.7					.7	
24				.36			.36	1:30P			.7					.7	
25					.36		.36	5:00P					.5			.5	
26					.41		.41	4:30P					.5			.5	
27				.39			.39	3:45P			.3					.3	
28				.38			.38	1:15P			.9					.9	
29					.36		.36	4:00P					1.2			1.2	
30					.28		.28	5:00P					1.2			1.2	
31					.25		.25	7:30P					1.0			1.0	

average .65

If at Any Time the combined filter effluent turbidity exceeds 5 NTU (>5.49), the state must be notified as soon as possible, but not later than the end of the next business day.