

Meadow Mountain
September 2008

MONTHLY OPERATIONAL REPORT - Data Sheet
SLOW SAND, DIATOMACEOUS EARTH & OTHER FILTRATION

FAVED
10-2-08

Required Number of Turbidity Readings Per Day:

PWSID #: 00-0207504

DAY	TURBIDITY (NTU)								RESIDUAL DISINFECTANT (mg/L)						12. COMMENTS
	☐ Continuous Sampling			☒ Grab Sampling					☐ Continuous Sampling			☒ Grab Sampling			
	12 to 4	4 to 8	8 to 12	12 to 4	4 to 8	8 to 12	HIGHEST TURBIDITY READING	TIME TURBIDITY READ	ENTRY POINT TO DISTRIBUTION						
									12 to 4	4 to 8	8 to 2	12 to 4	4 to 8	8 to 12	
1			.28				.28	3:30P				1.0			1.0
2			.35				.35	2:45P				1.0			1.0
3				.28			.28	4:00P					.8		.8
4				.45			.45	4:30P					.8		.8
5			.39				.39	3:45P				.8			.8
6				.32			.32	4:00P					.8		.8
7			.29				.29	9:50A			.14				.9
8				.39			.39	5:00P					1.1		1.1
9			.32				.32	12:15P				1.0			1.0
10			.33				.33	3:30P				1.1			1.1
11			.36				.36	10:30A			1.1				1.1
12			.36				.36	3:55P				.9			.9
13				.32			.32	4:15P					.9		.9
14			.29				.29	10:35A			.7				.7
15				.23			.23	5:15P					.8		.8
16				.20			.20	7:00P					1.0		1.0
17				.24			.24	4:20P					1.0		1.0
18			.28				.28	11:00A			1.0				1.0
19			.25				.25	11:30A			1.0				1.0
20				.28			.28	4:30P					1.0		1.0
21			.22				.22	9:30A			1.1				1.1
22				.29			.29	5:00P					1.0		1.0
23				.27			.27	4:15P					.9		.9
24				.20			.20	4:10P					1.0		1.0
25				.21			.21	4:20P					.9		.9
26				.23			.23	5:00P					.8		.8
27				.26			.26	5:15P					.9		.9
28				.25			.25	4:30P					1.1		1.1
29				.22			.22	5:15P					1.1		1.1
30				.18			.18	3:45					1.0		1.0
31															

If at Any Time the combined filter effluent turbidity exceeds 5 NTU (>5.49), the state must be notified as soon as possible, but not later than the end of the next business day.