

October 2008

MONTHLY OPERATIONAL REPORT - Data Sheet
SLOW SAND, DIATOMACEOUS EARTH & OTHER FILTRATION

Meadow Mountain W/S

Required Number of Turbidity Readings Per Day: 1

PWSID #: 0207504

DAY	TURBIDITY (NTU)								RESIDUAL DISINFECTANT (mg/L)								12. COMMENTS
	☐ Continuous Sampling ☒ Grab Sampling								☐ Continuous Sampling ☒ Grab Sampling								
	12 to 4	4 to 8	8 to 12	12 to 4	4 to 8	8 to 12	HIGHEST TURBIDITY READING	TIME TURBIDITY READ	ENTRY POINT TO DISTRIBUTION						LOWEST RESIDUAL READING		
									12 to 4	4 to 8	8 to 12	12 to 4	4 to 8	8 to 12			
1					.28		.28	4:00P					.8		.8		
2				.40			.40	12:10P				.8			.8		
3			.22				.22	11:30A			1.2				1.2		
4					.34		.34	4:30P					1.1		1.1		
5					.31		.31	5:30P					1.1		1.1		
6		.37					.37	7:05A		1.0					1.0		
7				.21			.21	12:30P				1.0			1.0		
8					.25		.25	4:00P					1.0		1.0		
9			.31				.31	11:30A			1.1				1.1		
10				.28			.28	3:30P				1.1			1.1		
11					.19		.19	4:05P					1.1		1.1		
12				.49			.49	2:00P				1.0			1.0		
13					.43		.43	5:15P					1.0		1.0		
14				.37			.37	12:30P				1.0			1.0		
15			.37				.37	11:00A			1.0				1.0		
16				.25			.25	3:30P				.9			.9		
17				.29			.29	3:30P				.9			.9		
18					.31		.31	5:30P					.9		.9		
19				.18			.18	2:50P				.8			.8		
20					.16		.16	5:00P					.9		.9		
21				.21			.21	12:45P				.9			.9		
22					.30		.30	4:30P					.8		.8		
23					.36		.36	4:15P					1.1		1.1		
24					.19		.19	4:15P					1.2		1.2		
25				.42			.42	3:00P				.9			.9		
26				.19			.19	1:20P				.8			.8		
27					.23		.23	5:00P					.7		.7		
28					.27		.27	4:05P					1.0		1.0		
29					.35		.35	4:40P					.8		.8		
30					.34		.34	4:40P					.9		.9		
31				.22			.22	3:45P				.8	.8		.8		

If at Any Time the combined filter effluent turbidity exceeds 5 NTU (>5.49), the state must be notified as soon as possible, but not later than the end of the next business day.