

NOV
2005

MONTHLY OPERATIONAL REPORT - Data Sheet
SLOW SAND, DIATOMACEOUS EARTH & OTHER FILTRATION

Required Number of Turbidity Readings Per Day: 1

PWSID #: 01-0207504

DAY	TURBIDITY (NTU)							RESIDUAL DISINFECTANT (mg/L)							12. COMMENTS		
	☐ Continuous Sampling ☒ Grab Sampling						HIGHEST TURBIDITY READING	TIME TURBIDITY READ	☐ Continuous Sampling ☒ Grab Sampling							LOWEST RESIDUAL READING	
	12 to 4	4 to 8	8 to 12	12 to 4	4 to 8	8 to 12			ENTRY POINT TO DISTRIBUTION								
										12 to 4	4 to 8	8 to 12	12 to 4	4 to 8	8 to 12		
1				.25			.25	2:00P					1.0				1.0
2			.24				.24	8:30A				1.0					1.0
3		.28					.28	7:15A		1.0							1.0
4					.20		.20	4:10P						.7			.7
5			.36				.36	11:00A						.9			.9
6			.36				.36	11:30A						.8			.3
7					.32		.32	6:45P						.9			.9
8						.34	.34	9:00P							.9		.9
9				.24			.24	1:00P				1.0					1.0
10			.51				.51	10:45A				1.2					1.2
11				.30			.30	1:00P				1.1					1.1
12			.22				.22	11:15A				1.1					1.1
13			.40				.40	11:00A				.9					.9
14				.29			.29	2:15P				.8					.8
15					.32		.32	6:30P					.9				.9
16				.21	.21		.21	12:00P				.7					.7
17					.19		.19	5:00P					.7				.7
18				.19			.19	2:00P				1.0					1.0
19			.29				.29	11:15A				1.2					1.2
20			.22				.22	11:30A				1.1					1.1
21			.38				.38	11:00A				.9					.9
22			.35				.35	11:15A				1.0					1.0
23				.49			.49	1:20P				1.0					1.0
24					.23		.23	5:00P					1.0				1.0
25			.45				.45	11:00A				1.0					1.0
26			.34				.34	10:30A				1.0					1.0
27				.32			.32	1:30P				1.0					1.0
28			.25				.25	9:30A				1.0					1.0
29						.28	.28	5:30P						1.0			1.0
30			.24				.24	11:10				0.4					0.4
31																	

If at Any Time the combined filter effluent turbidity exceeds 5 NTU (>5.49), the state must be notified as soon as possible, but not later than the end of the next business day.