

DEC 2008

STATE OF TEXAS
MONTHLY OPERATIONAL REPORT - Data Sheet
SLOW SAND, DIATOMACEOUS EARTH & OTHER FILTRATION

Meadow Mountain
WS

Required Number of Turbidity Readings Per Day: 1

PWSID #: 0-0207504

DAY	TURBIDITY (NTU)								RESIDUAL DISINFECTANT (mg/L)						12. COMMENTS	
	☐ Continuous Sampling			☒ Grab Sampling					☐ Continuous Sampling			☒ Grab Sampling				
	12 to 4	4 to 8	8 to 12	12 to 4	4 to 8	8 to 12	HIGHEST TURBIDITY READING	TIME TURBIDITY READ	ENTRY POINT TO DISTRIBUTION							LOWEST RESIDUAL READING
									12 to 4	4 to 8	8 to 2	12 to 4	4 to 8	8 to 12		
1		.24					.24	7:30A		1.0					1.0	
2			.25				.25	11:15A			.8				.8	
3				.28			.28	12:45P				1.0			1.0	
4				.32			.32	5:45P				1.0			1.0	
5		.25					.25	7:30A		.9					.9	
6					.36		.36	4:30P					1.1		1.1	
7				.20			.20	2:45P				1.0			1.0	
8				.51			.51	10:30A			1.0				1.0	
9				.47			.47	2:40P				1.0			1.0	
10				.40			.40	11:00A			1.0				1.0	
11				.20			.20	11:15A			1.1				1.1	
12				.30			.30	11:15A			1.0				1.0	
13					.32		.32	4:50P					1.0		1.0	
14					.28		.28	4:50P					1.0		1.0	
15				.23			.23	9:30A			1.0				1.0	
16					.32		.32	5:00P					1.0		1.0	
17					.37		.37	4:30P					.7		.7	
18				.19			.19	11:30A			.7				.7	
19					.28		.28	5:30P					.5		.5	
20				.30			.30	1:30P				.6			.6	
21					.23		.23	4:10P					0.9		.9	
22				.27			.27	10:45A			1.1				1.1	
23					.17		.17	4:30P					1.0		1.0	
24				.45			.45	12:00P				1.1			1.1	
25				.40			.40	9:15A			1.0				1.0	
26					.42		.42	1:15P				1.0			1.0	
27				.40			.40	2:30P				1.0			1.0	
28				.22			.22	9:45A			1.0				1.0	
29				.46			.46	10:30A			1.0				1.0	
30					.25		.25	2:00P				.9			.9	
31				.51			.51	2:00P				.8			.8	

If at Any Time the combined filter effluent turbidity exceeds 5 NTU (>5.49), the state must be notified as soon as possible, but not later than the end of the next business day.