

FAXED 11-3-08

2008

Year

10-0207504

Plant ID #:

City Zip

Population Served: _____

Responsible Party: Stephen Tedford

II. TURBIDITY SECTION [Slow Sand, Diatomaceous Earth, Other (i.e., Bag Filter)]

NO. OF SAMPLES	% OF TOTAL SAMPLES
-------------------	--------------------------

A. TOTAL NUMBER OF TURBIDITY ANALYSES PERFORMED	31	
B. NUMBER OF TURBIDITY ANALYSES ≤ 1 NTU	31	100%
C. NUMBER OF TURBIDITY ANALYSES > 5 NTU	0	

HIGHEST TURBIDITY READING OF THE MONTH 49

D. INDIVIDUAL TURBIDITY CHECKLIST (For Direct or Conventional Only)

1. IS TURBIDITY FROM EACH INDIVIDUAL FILTER RECORDED EVERY 15 MINUTES? ☐ YES ☐ NO
2. DID ANY SINGLE FILTER EXCEED 2.0 NTU IN 2 CONSECUTIVE 15 MINUTE PERIODS?
☐ NO, Go to Question 3.
☐ YES, What date was the Filter Profile completed? _____
DID THIS SAME FILTER EXCEED 2.0 NTU IN 2 CONSECUTIVE 15 MIN. PERIODS DURING THE LAST MONTH?
☐ NO, Go to Question 3.
☐ YES, Schedule Comprehensive Performance Evaluation (CPE) with 30 Days.
3. DID ANY SINGLE FILTER EXCEED 1.0 NTU IN 2 CONSECUTIVE 15 MINUTE PERIODS?
☐ NO, Go to Question 4.
☐ YES, What date was the Filter Profile completed? _____
DID THIS SAME FILTER EXCEED 1.0 NTU IN 2 CONSECUTIVE 15 MIN. PERIODS DURING THE LAST 2 MONTHS?
☐ NO, Go to Question 4.
☐ YES, What date was the Filter Self-assessment completed? _____
4. DID ANY SINGLE FILTER EXCEED 0.5 NTU IN 2 CONSECUTIVE 15 MIN. PERIODS AT THE END OF 4 HRS OF OPERATION?
☐ NO, You are finished with the checklist
☐ YES, What date was the Filter Profile completed? _____

**** NOTE: If any of the above questions are checked "YES", you must complete IESWTR Form 2 and submit to WQCD along with this form****

☐ FREE ☐ TOTAL

A. NO. OF CHLORINE RESIDUAL SAMPLES <0.2 mg/L:	2
B. NO. OF CHLORINE RESIDUAL SAMPLES TAKEN FROM DIST. SYSTEM:	31
C. NO. IN DISTRIBUTION SYSTEM WHERE NO CHLORINE WAS DETECTED:	0
D. % OF SAMPLES WHERE NO CHLORINE WAS DETECTED:	0

WAS % IN "D" > 5% IN THE PREVIOUS MONTH: ☐ YES ☒ NO

*** NOTE: If answer to above question is "YES" and percentage for current month is also > 5%, this is a Treatment Technique (TT) violation***