



Colorado Department  
of Public Health  
and Environment

## Colorado Department of Public Health and Environment Compliance Assurance & Data Management Unit

### REPORTING FORM FOR INORGANIC CONTAMINANTS ANALYSES

SAMPLER: FILL OUT ONE FORM FOR EACH SAMPLE

Are these results to be used to fulfill compliance monitoring requirements? YES ☒ or NO ☐

Is this a check or confirmation sample? ☐ YES ☒ NO

PWSID CO0207504 COUNTY: Boulder DATE COLLECTED: 03/19/08

SYSTEMS NAME: Meadow Mountain Water Company

SYSTEM MAILING ADDRESS: P.O.Box 162 Allenspark CO 80510  
Street address/PO Box CITY STATE ZIP

CONTACT PERSON: Steve Tedford PHONE: (303) 747-2066

SAMPLE COLLECTED BY: Steve Tedford TIME COLLECTED: 8:15 am

ENTRY POINT (Finished Water) SAMPLE ☒ SOURCE WATER SAMPLE ☐

FOR ENTRY POINT SAMPLE PLEASE INDICATE: Chlorinated ☒ Other Treatment ☐

Finished—Not Treated (No chlorine or other treatment) ☐

STATE ENTRY POINT CODE: EP Distribution SOURCE(S) REPRESENTED: Surface Water

DO SAMPLES NEED TO BE COMPOSITED BY THE LABORATORY? YES ☐ NO ☒

NOTE: CHECK OR CONFIRMATION SAMPLES CANNOT BE COMPOSITED

*For Laboratory Use Only Below This Line*

LABORATORY SAMPLE # 801784 CLIENT NAME or ID# Meadow Mountain Water Company (1115-018)

LABORATORY NAME Stewart Environmental Consultants, Inc.

LAB PHONE #: (970) 226-5500 DATE RECEIVED IN LABORATORY 03/19/08

COMMENTS:

| PARAMETER | RESULT in<br>(mg/L) | MCL in<br>(mg/L) | STANDARD<br>METHOD | Lab MDL in<br>(mg/L) | Date Analyzed |
|-----------|---------------------|------------------|--------------------|----------------------|---------------|
| Antimony  | BDL                 | 0.006            | 200.9              | 0.005                | 04/01/08      |
| Arsenic   | BDL                 | 0.05/0.010*      | 200.9              | 0.005                | 04/01/08      |
| Barium    | BDL                 | 2.0              | 200.7              | 0.001                | 03/27/08      |
| Beryllium | 0.0005              | 0.004            | 200.7              | 0.0003               | 03/27/08      |
| Cadmium   | BDL                 | 0.005            | 200.9              | 0.001                | 04/02/08      |
| Chromium  | BDL                 | 0.1              | 200.7              | 0.01                 | 03/27/08      |
| Cyanide   | NT                  | 0.2              | 4500CN-C-E         |                      |               |
| Fluoride  | 0.1                 | 4.0              | 4500F-C            | 0.1                  | 03/20/08      |
| Mercury   |                     | 0.002            | 245.1              |                      |               |
| Nickel    | BDL                 | **               | 200.7              | 0.01                 | 03/27/08      |
| Selenium  | BDL                 | 0.05             | 200.9              | 0.005                | 03/31/08      |
| Sodium    | 3.3                 | **               | 200.7              | 0.01                 | 03/27/08      |
| Thallium  | BDL                 | 0.002            | 200.9              | 0.002                | 04/01/08      |

\* 0.010 mg/L is effective January 2006

\*\* Monitoring is required, but there is no MCL for this contaminant

M. Slavavovich Laboratory Manager  
Reviewed & Approved by Title

05/09/08  
Date

MAIL RESULTS TO: CDPHE, WQCD-CADM  
4300 Cherry Creek Drive South  
Denver, CO 80246-1530

FAX: 303-782-0390