



Colorado Department
of Public Health
and Environment

Colorado Department of Public Health and Environment Compliance Assurance & Data Management Unit

REPORTING FORM FOR NITRATE OR NITRITE AS NITROGEN ANALYSES

SAMPLER: FILL OUT ONE FORM - FOR EACH INDIVIDUAL SAMPLING POINT

Are these results to be used to fulfill compliance monitoring requirements? YES ☒ or NO ☐

Is this a check or confirmation sample? ☐ YES ☒ NO

PWSID CO0 207504 COUNTY: Boulder DATE COLLECTED 03/19/08

SYSTEMS NAME: Meadow Mountain Water Company

SYSTEM MAILING ADDRESS: P.O. Box 162 Allenspark CO 80510
Street address/PO Box CITY STATE ZIP

CONTACT PERSON: Steve Tedford PHONE: (303) 747-2066

SAMPLE COLLECTED BY: Steve Tedford TIME COLLECTED: 8:15 am/pm

ENTRY POINT (Finished Water) SAMPLE ☒ SOURCE WATER SAMPLE ☐

FOR ENTRY POINT SAMPLES PLEASE INDICATE: Chlorinated ☒ Other Treatment ☐
Finished—Not Treated (No chlorine or other treatment) ☐

STATE ENTRY POINT CODE: EP Distribution SOURCE(S) REPRESENTED: Surface Water

For Laboratory Use Only Below This Line

LABORATORY SAMPLE # 801786 CLIENT NAME or ID# Meadow Mountain Water Company #1115-018

LABORATORY NAME Stewart Environmental Consultants, Inc.

LAB PHONE # (970) 226-5500 DATE RECEIVED IN LABORATORY 03/19/08

COMMENTS: _____

PARAMETER	RESULT	UNITS	MCL	STANDARD METHOD	LAB MDL	DATE ANALYZED
Nitrate as N	BDL	mg/L	10.0 mg/L	4500NO3-E	0.5 mg/L	03/20/08
Nitrite as N	NT	mg/L	1.0 mg/L	4500N02-B	mg/L	

M. Slavovick Laboratory Manager 05/09/08
Reviewed & Approved by Title Date

MAIL RESULTS TO: CDPHE, WQCD-CADM
4300 Cherry Creek Drive South
Denver, CO 80246-1530

FAX: 303-782-0390