

# STATE OF COLORADO

Bill Ritter, Jr., Governor  
James B. Martin, Executive Director

Dedicated to protecting and improving the health and environment of the people of Colorado

4300 Cherry Creek Dr. S.  
Denver, Colorado 80246-1530  
Phone (303) 692-2000  
TDD Line (303) 691-7700  
Located in Glendale, Colorado

Laboratory Services Division  
8100 Lowry Blvd.  
Denver, Colorado 80230-6928  
(303) 692-3090

<http://www.cdphe.state.co.us>



Colorado Department  
of Public Health  
and Environment

August 25, 2008

Mr. Steve Tedford  
Meadow Mountain WS, CO0207504  
PO Box 394  
Allenspark, CO 80510

## REVISED DRINKING WATER MONITORING SCHEDULE FOR RADIONUCLIDES

Dear Mr. Tedford:

Meadow Mountain WS's 2008 Drinking Water Monitoring Schedule has been revised in accordance with Section 6.3.2(b)(4) of the *Colorado Primary Drinking Water Regulations*. After completing two (2) consecutive quarters with results less than the regulatory detection level, the requirement to monitor for the last two (2) quarters of the initial four (4) consecutive quarters has been waived.

A revised 2008 Monitoring Schedule, detailing new and forward-going sampling requirements, is attached. Please begin monitoring in accordance with the revised schedule and discard any previously provided schedules.

If you have any questions, please contact me at 303-692-3617 or by e-mail to [jackie.whelan@state.co.us](mailto:jackie.whelan@state.co.us).

Sincerely,

Jacalyn M. Whelan, EPS II  
Drinking Water Rule Manager  
Drinking Water Compliance Assurance Unit  
Water Quality Control Division

cc: Drinking Water File

Enclosure