



Colorado Department  
of Public Health  
and Environment

Colorado Department of Public Health and Environment  
Compliance Assurance & Data Management Unit

RECEIVED  
SEP 26 2009

REPORTING FORM FOR BACTERIOLOGICAL ANALYSIS

SAMPLER: FILL OUT ONE FORM - FOR EACH INDIVIDUAL SAMPLING POINT

PWSID #: CO0 207504 COUNTY: \_\_\_\_\_ DATE COLLECTED: 9.1.09  
SYSTEM/ESTABLISHMENT NAME: MEADOW MOUNTAIN WATER  
SYSTEM MAILING ADDRESS: \_\_\_\_\_

CONTACT PERSON: STEVE TEDFORD CITY: \_\_\_\_\_ STATE: \_\_\_\_\_ ZIP: \_\_\_\_\_  
PHONE: (970)  
SAMPLE COLLECTED BY: STEVE TEDFORD TIME COLLECTED: 7:15 am/pm  
WATER TYPE: RAW (No chlorine or other treatment) ☐ CHLORINATED ☒ OTHER TREATMENT ☐

SAMPLE POINT (Address)	CHLORINE RESIDUAL in mg/L	SAMPLE TYPE
<u>FINISHED</u>	<u>1.0</u>	<input checked="" type="checkbox"/> Routine <input type="checkbox"/> Repeat <input type="checkbox"/> Special Purpose

For Laboratory Use Only Below This Line  
LABORATORY SAMPLE # 20091115 CLIENT NAME or ID# MEADOW MOUNTAIN WATER  
LABORATORY NAME: CHD DIAGNOSTIC & CONSULTING LAB PHONE # 970 532 2078  
DATE RECEIVED IN LABORATORY 9.1.09 DATE ANALYZED 9.2.09  
COMMENTS: NTU < 0.28

PARAMETER	RESULT	UNITS	ANALYSIS DATE	LABORATORY METHOD
Coliform, TOTAL (Verified)		#/100 mL		
Coliform, FECAL/e. Coli (Verified)		#/100 mL		
Coliform, TOTAL (Absent/Present)	<u>ABSENT</u>		<u>9/2/09</u>	<u>Colilert 24</u>
Coliform, FECAL/e. Coli (Absent/Present)				

LABORATORY: Please call Drinking Water Section with any results other than < 1 or ABSENT.

NT = Not Tested for compound

TNTC = Too Numerous To Count - Please resample

OD = Outdated - Please resample

<1 = Safe valid sample

Present Coliform / e. Coli / Fecal detected

#/100 ml = Number of colonies per 100 ml of sample

CG = Confluent Growth - Please resample

LA = Lab Accident - Please resample

Absent = Coliform / e. Coli / Fecal not detected

7/2/09 Reviewed & Approved by \_\_\_\_\_ Title \_\_\_\_\_ Date 9.22.09

MAIL RESULTS TO: CDPHE, WQCD-CADM-B2, 4300 Cherry Creek Drive South, Denver, CO 80246-1530

RECEIVED

SEP 26 2009

## LABORATORY ANALYTICAL REPORT

**Customer** 20011350  
Meadow Mountain Water  
PO Box 354  
Allenspark, CO 80510  
**PWSID:** CO 0207504

**Invoice Number:** 20091115  
**Received Date & Time:** 9/1/2009 9:35AM  
**Arrival Temperature:** 12.6°C

**Sample Identification:** Finished

**Sample Information:** Stream or River, Chlorinated; .28 NTU

**Sample Date & Time:** 9/1/2009 7:15AM

**Sampler:** Steve Tedford

**Volume Sampled:** 100ml

**Sample Type:** Grab

**Processing Date & Time:** 9/1/2009 1:21PM

**Analytical Method:** 9223B, IDEXX Colilert® with QuantiTray® 2000

**Start Date & Time:** 9/1/2009 1:21PM

**Amount Analyzed:** 100ml

**Stop Date & Time:** 9/2/2009 1:21PM

**Additional Start Date & Time:** N/A

**Dilution factor:** N/A

**Additional Stop Date & Time:** N/A


**Analytical Results:**

**Analyte Reporting Limit:** 1.0

**Coliform bacteria:** ABSENT

**Chlorine Residual:** 1

This sample was analyzed for the presence of Escherichia coli (E. coli) by the method outlined in: Standard Methods for the Examination of Water and Wastewater, 20th Edition, 1998, 9223 B, Enzyme Substrate Test. All limitations stated in the method apply.

  
**Report Approved By**

**Title**

**Date**

CH Diagnostic Consulting Service, Inc.  
512 5th Street, Berthoud CO 80513  
PH: (970) 532 2078 FX: (970) 532 3358