

January 2009

MONTHLY OPERATIONAL REPORT - Data Sheet
SLOW SAND, DIATOMACEOUS EARTH & OTHER FILTRATION

Required Number of Turbidity Readings Per Day: 1

PWSID #: 00-0207504

DAY	TURBIDITY (NTU)							RESIDUAL DISINFECTANT (mg/L)							12. COMMENTS		
	☐ Continuous Sampling ☒ Grab Sampling						HIGHEST TURBIDITY READING	TIME TURBIDITY READ	☐ Continuous Sampling ☒ Grab Sampling							LOWEST RESIDUAL READING	
	12 to 4	4 to 8	8 to 12	12 to 4	4 to 8	8 to 12			ENTRY POINT TO DISTRIBUTION								
										12 to 4	4 to 8	8 to 12	12 to 4	4 to 8	8 to 12		
1					.24		.24	4:00P						.7		.7	
2					.28		.28	4:30P						.6		.6	
3				.30			.30	2:15P					.7			.7	
4					.24		.24	6:45P						.7		.7	
5		.26					.76	7:15A		.7						.7	
6				.34			.34	1:00P					.5			.5	
7			.34				.34	4:20P			.6					.6	
8				.38			.38	2:10P					.6			.6	
9				.23			.23	2:00P					.5			.5	
10			.70				.20	9:30A			1.0					1.0	
11					.22		.22	5:20P					1.0			1.0	
12				.28			.28	3:45P					1.0			1.0	
13				.22			.22	2:00P					.9			.9	
14				.26			.26	2:45P					.9			.9	
15			.46				.46	11:30A			1.1					1.1	
16					.49		.49	4:00P					1.0			1.0	
17						.42	.42	6:00P							1.0	1.0	
18					.25		.25	7:00P					1.5			1.5	
19			.50				.50	10:30A			1.5					1.5	
20		.42					.42	7:30A		1.1						1.1	
21					.24		.24	4:00P						.9		.9	
22				.36			.36	3:45P					.9			.9	
23					.41		.41	4:30P					1.1			1.1	
24				.28			.28	2:15P					.7			.7	
25			.27				.27	11:30A			1.0					1.0	
26			.28				.28	9:15A			1.0					1.0	
27			.26				.26	9:00A			1.0					1.0	
28				.31			.31	12:15P				1.0				1.0	
29			.21				.21	11:15A			1.1					1.1	
30				.27			.27	2:00P				1.0				1.0	
31			.27				.27	11:00P			.8					.8	

If at Any Time the combined filter effluent turbidity exceeds 5 NTU (>5.49), the state must be notified as soon as possible, but not later than the end of the next business day.