

March 2019

MONTHLY OPERATIONAL REPORT - Data Sheet
SLOW SAND, DIATOMACEOUS EARTH & OTHER FILTRATION

Required Number of Turbidity Readings Per Day: 1

PWSID #: 000207504

DAY	TURBIDITY (NTU)								RESIDUAL DISINFECTANT (mg/L)								12. COMMENTS
	☐ Continuous Sampling ☒ Grab Sampling						HIGHEST TURBIDITY READING	TIME TURBIDITY READ	☐ Continuous Sampling ☒ Grab Sampling						LOWEST RESIDUAL READING		
	12 to 4	4 to 8	8 to 12	12 to 4	4 to 8	8 to 12			ENTRY POINT TO DISTRIBUTION								
										12 to 4	4 to 8	8 to 12	12 to 4	4 to 8	8 to 12		
1			.18				.18	10:00A				1.0				1.0	
2			.14				.14	11:00A				1.0				1.0	
3					.17		.17	4:00P						.9		.9	
4				.16			.16	3:00P				1.0				1.0	
5			.18				.18	8:15A				1.0				1.0	
6			.16				.16	9:15A				1.0				1.0	
7				.15			.15	2:00P				1.0				1.0	
8				.14			.14	12:00P				1.0		1.0		1.0	
9					.29		.29	4:30P						1.0		1.0	
10					.18		.18	4:15P						1.0		1.0	
11			.20				.20	11:15A				1.0	1.0			1.0	
12					.25		.25	4:15P						1.0		1.0	
13			.22				.22	9:00A				1.0				1.0	
14				.58			.58	12:00P					1.0			1.0	
15				.23			.23	1:20P					1.0			1.0	
16			.29				.29	10:45A				.9				.9	
17		.76					.76	7:20A			.9					.9	
18					.23		.23	4:30P						.9		.9	
19					.22		.22	4:15P						.9		.9	
20				.24			.24	2:20P					.8			.8	
21			.24				.24	3:10P					.9			.9	
22			.24				.24	4:30P						1.3		1.3	
23			.30				.30	5:30A						1.1		1.1	
24			.76				.76	4:15A				1.0				1.0	
25			.29				.29	3:45P					1.0			1.0	
26			.78				.78	4:15P					1.0			1.0	
27			.78				.78	3:45P			1.0					1.0	
28			.25				.25	2:30P					.8			.8	
29			.35				.35	3:50P					.8			.8	
30			.30				.30	3:20P					.9			.9	
31			.31				.31	5:05P					.9			.9	

If at Any Time the combined filter effluent turbidity exceeds 5 NTU (>5.49), the state must be notified as soon as possible, but not later than the end of the next business day.