

April 2009

MONTHLY OPERATIONAL REPORT - Data Sheet
SLOW SAND, DIATOMACEOUS EARTH & OTHER FILTRATION

Required Number of Turbidity Readings Per Day: 1

PWSID #: 00-0207504

DAY	TURBIDITY (NTU)							RESIDUAL DISINFECTANT (mg/L)							12. COMMENTS	
	☐ Continuous Sampling ☒ Grab Sampling						HIGHEST TURBIDITY READING	TIME TURBIDITY READ	☐ Continuous Sampling ☒ Grab Sampling							LOWEST RESIDUAL READING
	12 to 4	4 to 8	8 to 12	12 to 4	4 to 8	8 to 12			ENTRY POINT TO DISTRIBUTION							
										12 to 4	4 to 8	8 to 12	12 to 4	4 to 8	8 to 12	
1		.28		.28			.28	7:45A		.9				.9		
2				.25		.25	.25	8:15P						.9		
3				.24			.24	2:10P					.7			
4				.28			.28	2:15P					.8			
5			.25				.25	11:45A			.8					
6						.24	.24	8:30P						.8		
7				.32			.32	3:45P					1.0			
8			.24				.24	11:45A			1.0					
9			.24				.24	11:00A			.9					
10			.20				.26	11:15P			.9					
11				.28			.28	3:20P				.9				
12			.30				.30	10:00A			1.0					
13			.37				.37	11:30A			1.0					
14				.40			.40	3:10P				1.0				
15			.35				.35	10:00A			1.0					
16			.35				.35	2:15P				1.1				
17			.38				.38	3:45P				1.0				
18				.40			.40	7:45P					1.0			
19				.51			.51	6:00P					.8			
20				.48			.48	5:00P					.7			
21				.48			.48	4:30P					.8			
22			.69				.69	2:00P				1.0				
23			1.04				1.04	3:00P				1.0				
24			.92				.92	5:30P				1.0				
25			.87				.87	2:35P				1.0				
26				2.12			2.12	5:50P					1.0			
27				2.15			2.15	4:15P					.9			
28				1.61			1.61	3:00P				1.0				
29			1.72				1.72	8:45A			1.0					
30				1.78			1.78	4:00P					.9			
31																

If at Any Time the combined filter effluent turbidity exceeds 5 NTU (>5.49), the state must be notified as soon as possible, but not later than the end of the next business day.