

May 2009

MONTHLY OPERATIONAL REPORT - Data Sheet
SLOW SAND, DIATOMACEOUS EARTH & OTHER FILTRATION

Required Number of Turbidity Readings Per Day: 1

PWSID #: 000207504

DAY	TURBIDITY (NTU)								RESIDUAL DISINFECTANT (mg/L)								12. COMMENTS
	☐ Continuous Sampling ☒ Grab Sampling						HIGHEST TURBIDITY READING	TIME TURBIDITY READ	☐ Continuous Sampling ☒ Grab Sampling						LOWEST RESIDUAL READING		
	12 to 4	4 to 8	8 to 12	12 to 4	4 to 8	8 to 12			ENTRY POINT TO DISTRIBUTION								
1			1.75				1.75	8:15A			.9					.9	
2			1.63				1.63	11:30A			.9					.7	
3					1.61		1.61	4:50P					1.0			1.0	
4					1.88		1.88	5:19P					1.1			1.1	
5				1.95			1.95	1:00P				1.0				1.0	
6			1.82				1.82	11:45A			1.0					1.0	
7					1.90		1.90	7:50P					1.0			1.0	
8			1.84				1.84	10:45A			1.0					1.0	
9					2.43		2.43	4:10P					.6			.6	
10				2.25			2.25	1:10P				.7				.7	
11				2.22			2.22	2:45P				.9				.9	
12					1.93		1.93	4:30P					1.0			1.0	
13					2.05		2.05	4:15P					1.0			1.0	
14			1.77				1.77	11:30A			.8					.8	
15			1.72				1.72	6:00P			.9					.9	
16					1.92		1.92	4:40P					.9			.9	
17			1.29				1.29	10:30A			.9					.9	
18			1.43				1.43	11:30A			.7					.7	
19				1.02			1.02	3:30P				.5				.5	
20				.97			.97	3:30P				.8				.8	
21				1.14			1.14	3:30P				.5				.5	
22					.83		.83	4:30P					.8			.8	
23					.70		.70	5:30P					.9			.9	
24				.62			.62	12:20P			.8					.8	
25			.65				.65	10:30A			.7					.7	
26			.72				.72	5:15A			.6					.6	
27					.61		.61	4:40P					.7			.7	
28			.65				.65	4:30P			.5					.5	
29			.62				.62	10:15A			.5					.5	
30				.40			.40	3:30P				.9				.9	
31					.40		.40	4:50P					.8			.8	

If at Any Time the combined filter effluent turbidity exceeds 5 NTU (>5.49), the state must be notified as soon as possible, but not later than the end of the next business day.