

JUL 07 2009

MONTHLY OPERATIONAL REPORT - Data Sheet

SLOW SAND, DIATOMACEOUS EARTH & OTHER FILTRATION

Required Number of Turbidity Readings Per Day: 1

PWSID #: 00-0207504

| DAY | TURBIDITY (NTU) | | | | | | | | RESIDUAL DISINFECTANT (mg/L) | | | | | | | | 12. COMMENTS |
|-----|--|--------|---------|---------|--------|---------|---------------------------------|---------------------------|--|---------|--------|---------|---------|--------|-------------------------------|-----|--------------|
| | <input type="checkbox"/> Continuous Sampling <input checked="" type="checkbox"/> Grab Sampling | | | | | | HIGHEST TURBIDITY READING | TIME TURBIDITY READ | <input type="checkbox"/> Continuous Sampling <input checked="" type="checkbox"/> Grab Sampling | | | | | | LOWEST RESIDUAL READING | | |
| | 12 to 4 | 4 to 8 | 8 to 12 | 12 to 4 | 4 to 8 | 8 to 12 | | | ENTRY POINT TO DISTRIBUTION | | | | | | | | |
| | | | | | | | | | | 12 to 4 | 4 to 8 | 8 to 12 | 12 to 4 | 4 to 8 | 8 to 12 | | |
| 1 | | | | | .35 | | .35 | 5:15P | | | | | | 1.0 | | | |
| 2 | | | .34 | | | | .34 | 8:15A | | | | | .5 | | | .5 | |
| 3 | | | .29 | | | | .29 | 11:30A | | | | | .7 | | | .7 | |
| 4 | | | .37 | | | | .37 | 10:45A | | | | | .7 | | | .7 | |
| 5 | | | .32 | | | | .32 | 9:15A | | | | | .8 | | | .8 | |
| 6 | | | .36 | | | | .36 | 10:15A | | | | | .8 | | | .8 | |
| 7 | | | | | .40 | | .40 | 6:20P | | | | | .7 | | | .7 | |
| 8 | | .32 | | | | | .32 | 7:00A | | .5 | | | .8 | | | .8 | |
| 9 | | | | .36 | | | .36 | 1:30P | | | | | .8 | | | .8 | |
| 10 | | | | .32 | | | .32 | 2:00P | | | | | .8 | | | .8 | |
| 11 | | | | | .23 | | .23 | 4:30P | | | | | .5 | | | .5 | |
| 12 | | | .25 | | | | .25 | 11:00A | | | .6 | | | | | .6 | |
| 13 | | | | .35 | | | .35 | 3:00P | | | | 1.2 | | | | 1.2 | |
| 14 | | | | | .21 | | .21 | 7:00P | | | | | .09 | | | .09 | |
| 15 | | | | | .26 | | .26 | 5:20P | | | | | .8 | | | .8 | |
| 16 | | | | .26 | | | .26 | 3:00P | | | | | .8 | | | .8 | |
| 17 | | | .26 | | | | .26 | 9:30A | | | .8 | | | | | .8 | |
| 18 | | | | .23 | | | .23 | 3:15P | | | | 1.2 | | | | 1.2 | |
| 19 | | | .18 | | | | .18 | 11:00A | | | | | 1.1 | | | 1.1 | |
| 20 | | | | | .24 | | .24 | 6:45P | | | | | 1.0 | | | 1.0 | |
| 21 | | | .26 | | | | .26 | 10:40A | | | 1.0 | | | | | 1.0 | |
| 22 | | | | | .26 | | .26 | 4:30P | | | | | .7 | | | .7 | |
| 23 | | | .28 | | | | .28 | 9:30A | | | .8 | | | | | .8 | |
| 24 | | | .26 | | | | .26 | 8:00A | | | .8 | | | | | .8 | |
| 25 | | | .42 | | | | .42 | 11:00A | | | .7 | | | | | .7 | |
| 26 | | | .35 | | | | .35 | 9:15A | | | .7 | | | | | .7 | |
| 27 | | | | .26 | | | .26 | 3:00P | | | | 1.1 | | | | 1.1 | |
| 28 | | | .24 | | | | .24 | 10:30A | | | 1.3 | | | .7 | | 1.3 | |
| 29 | | | | | .24 | | .24 | 5:00P | | | | | 1.1 | | | 1.1 | |
| 30 | | | | | .33 | | .33 | 4:30P | | | | | 1.2 | | | 1.2 | |
| 31 | | | | | | | | | | | | | | | | | |

If at Any Time the combined filter effluent turbidity exceeds 5 NTU (>5.49), the state must be notified as soon as possible, but not later than the end of the next business day.