

July 2009

COLORADO DEPARTMENT OF PUBLIC HEALTH AND ENVIRONMENT
MONTHLY OPERATIONAL REPORT - Data Sheet
SLOW SAND, DIATOMACEOUS EARTH & OTHER FILTRATION

Meadow Mountain WS

Required Number of Turbidity Readings Per Day: 1

PWSID #: C-D 207504

DAY	TURBIDITY (NTU)								RESIDUAL DISINFECTANT (mg/L)								12. COMMENTS
	☐ Continuous Sampling ☒ Grab Sampling						HIGHEST TURBIDITY READING	TIME TURBIDITY READ	☐ Continuous Sampling ☒ Grab Sampling						LOWEST RESIDUAL READING		
	ENTRY POINT TO DISTRIBUTION																
	12 to 4	4 to 8	8 to 12	12 to 4	4 to 8	8 to 12			12 to 4	4 to 8	8 to 12	12 to 4	4 to 8	8 to 12			
1				.26			.26	3:45P					1.1			1.1	
2				.18			.18	12:00P					1.0			1.0	
3				.20			.20	2:45P					.8			.8	
4				.22			.22	1:45P					.6			.6	
5				.26			.26	3:00P					1.0			1.0	
6			.25				.25	10:00A			1.2					1.2	
7			.21				.21	10:30A			1.1					1.1	
8		.25					.25	7:30A		1.0						1.0	
9				.37			.37	3:30P					1.0			1.0	
10				.38			.38	12:00P					1.0			1.0	
11				.27			.27	2:15P					1.0			1.0	
12			.16				.16	10:00A			1.0		.9			.9	
13					.17		.17	4:00P						1.0		1.0	
14				.14			.14	2:00P					1.0			1.0	
15				.18			.18	3:30P					1.0			1.0	
16			.28				.28	11:30A			.9					.9	
17				.15			.15	3:30P					1.0			1.0	
18				.41			.41	3:00P			1.0		1.0			1.0	
19				.24			.24	2:15P					1.0			1.0	
20		.22					.22	7:15A		1.0						1.0	
21				.19			.19	10:00A					1.0			1.0	
22				.16			.16	3:30P					1.0			1.0	
23			.24				.24	11:15A			1.1					1.1	
24				.19			.19	3:45P					1.1			1.1	
25				.16			.16	3:30P					1.0			1.0	
26			.16				.16	10:30A			0.3					0.3	
27					.24		.24	5:00P						5		5	
28				.23			.23	7:45P					.9			.9	
29				.40			.40	3:30P					1.3			1.3	
30					.32		.32	5:00P						1.0		1.0	
31		.34					.34	1:45P		1.0						1.0	

RECEIVED

AUG 09 2009

If at Any Time the combined filter effluent turbidity exceeds 5 NTU (>5.49), the state must be notified as soon as possible, but not later than the end of the next business day.