

September 2009

**COLORADO DEPARTMENT OF PUBLIC HEALTH AND ENVIRONMENT
MONTHLY OPERATIONAL REPORT - Data Sheet
SLOW SAND, DIATOMACEOUS EARTH & OTHER FILTRATION**

Meadow Mountain
W.S.

Required Number of Turbidity Readings Per Day: 1

PWSID #: 0207504

DAY	TURBIDITY (NTU)								RESIDUAL DISINFECTANT (mg/L)								12. COMMENTS
	☐ Continuous Sampling ☒ Grab Sampling						HIGHEST TURBIDITY READING	TIME TURBIDITY READ	☐ Continuous Sampling ☒ Grab Sampling						LOWEST RESIDUAL READING		
	12 to 4	4 to 8	8 to 12	12 to 4	4 to 8	8 to 12			12 to 4	4 to 8	8 to 12	12 to 4	4 to 8	8 to 12			
1		.28					.28	7:15A		1.0					1.0		
2				.28			.28	3:45P				1.0			1.0		
3			.21				.21	11:00A			1.1				1.1		
4			.16				.16	11:15A			1.0				1.0		
5					.19		.19	6:30P				1.0			1.0		
6				.14			.14	12:20P			0.8				0.8		
7			.18				.18	10:00A			.8				.8		
8					.19		.19	4:00P				1.0			1.0		
9					.15		.15	4:00P				1.0			1.0		
10				.18			.18	1:45P				1.0			1.0		
11				.22			.22	3:40P				1.1			1.1		
12				.24			.24	3:00P				1.0			1.0		
13			.19				.19	11:20A			0.9				0.9		
14					.15		.15	5:00P					1.0		1.0		
15		.18					.18	7:30A		1.0					1.0		
16				.18			.18	3:00P				1.0			1.0		
17				.17			.17	3:00P				1.0			1.0		
18			.19				.19	10:30A			1.0				1.0		
19					.16		.16	5:30A					1.0		1.0		
20				.17			.17	12:15P			1.0				1.0		
21					.15		.15	4:30P					1.0		1.0		
22				.23			.22	3:45P				.9			.9		
23					.23		.23	4:30P					.9		.9		
24			.35				.35	11:00A			.9				.9		
25					.25		.25	4:00P					.9		.9		
26			.23				.23	10:30A			1.0				1.0		
27			.17				.17	10:20A			1.0				1.0		
28					.16		.16	4:45P					.9		.9		
29					.20		.20	4:00P					.9		.9		
30				.26			.26	3:30P				.9			.9		
31																	

RECEIVED
OCT 16 2009
RECEIVED
OCT 16 2009

If at Any Time the combined filter effluent turbidity exceeds 5 NTU (>5.49), the state must be notified as soon as possible, but not later than the end of the next business day.