

OCTOBER 2009

COLORADO DEPARTMENT OF PUBLIC HEALTH AND ENVIRONMENT
MONTHLY OPERATIONAL REPORT - Data Sheet
SLOW SAND, DIATOMACEOUS EARTH & OTHER FILTRATION

Meadow mt US

Required Number of Turbidity Readings Per Day: 1

PWSID #: C0-D204504

DAY	TURBIDITY (NTU)								RESIDUAL DISINFECTANT (mg/L)								RECEIVED OCT 31 2009 12. COMMENTS
	☐ Continuous Sampling ☒ Grab Sampling						HIGHEST TURBIDITY READING	TIME TURBIDITY READ	☐ Continuous Sampling ☒ Grab Sampling						LOWEST RESIDUAL READING		
	12 to 4	4 to 8	8 to 12	12 to 4	4 to 8	8 to 12			ENTRY POINT TO DISTRIBUTION								
1			.28				.28	8:15A				1.0				1.0	
2				.19			.19	3:45P				.8				.8	
3				.21			.21	2:30P				.9				.9	
4			.17				.17	11:00A				0.6				.6	
5					.14		.14	5:15P						.3		.8	
6			.18				.18	10:30A				.7				.7	
7				.20			.20	2:00P				1.0				1.0	
8			.15				.15	11:00A				1.0				1.0	
9			.20				.20	11:30A				.8				.8	
10				.15			.15	3:45P				.5				.5	
11					.20		.20	7:30P						0.0		0.0	
12			.23				.23	11:00A								.5	
13			.33				.33	10:00A				.5				.5	
14		.28					.28	7:30A			.6					.6	
15					.14		.14	4:00P						1.5		1.5	
16					.25		.25	4:00P						1.3		1.3	
17				.25			.25	2:30P				1.5				1.5	
18			.23				.23	2:40A				.7				.7	
19					.29		.29	4:30P						.6		.6	
20					.28		.28	4:40P						1.0		1.0	
21						.26	.26	5:00P							1.0	1.0	
22			.24			.24	.24	11:00A				1.0				1.0	
23				.16			.16	3:00P					1.0			1.0	
24				.20			.20	3:15P					1.0			1.0	
25			.22				.22	11:00A				1.0				1.0	
26					.14		.14	5:00P						1.2		1.2	
27					.18		.18	4:30P						1.1		1.1	
28					.20		.20	4:00P						1.6		1.6	
29					.15		.15	5:50P						1.0		1.0	
30				.20			.20	3:30P					1.0			1.0	
31				.24			.24	3:00P					1.1			1.1	

If at Any Time the combined filter effluent turbidity exceeds 5 NTU (>5.49), the state must be notified as soon as possible, but not later than the end of the next business day.