

COLORADO DEPARTMENT OF PUBLIC HEALTH AND ENVIRONMENT
MONTHLY OPERATIONAL REPORT - Data Sheet
SLOW SAND, DIATOMACEOUS EARTH & OTHER FILTRATION

Required Number of Turbidity Readings Per Day: 1

PWSID #: *CO-0207504*

DAY	TURBIDITY (NTU)								RESIDUAL DISINFECTANT (mg/L)								12. COMMENTS
	☐ Continuous Sampling ☒ Grab Sampling						HIGHEST TURBIDITY READING	TIME TURBIDITY READ	☐ Continuous Sampling ☒ Grab Sampling						LOWEST RESIDUAL READING		
	12 to 4	4 to 8	8 to 12	12 to 4	4 to 8	8 to 12			ENTRY POINT TO DISTRIBUTION								
1				.23			.23	2:00					0.7			0.7	
2					.20		.20	4:45P					.7			.7	
3				.14			.14	12:30					1.0			1.0	
4					.17		.17	4:20P					.9			.9	
5					.23		.23	4:15P					1.0			1.0	
6				.37			.37	3:10P					1.0			1.0	
7				.23			.23	3:30P					1.0			1.0	
8					.18		.18	4:20P					1.0			1.0	
9					.20		.20	5:00P					1.0			1.0	
10						.20	.20	8:30P						1.0		1.0	
11		.22					.22	7:15A		1.0						1.0	
12			.28				.28	11:00A			1.0					1.0	
13					.25		.25	4:00P					1.1			1.1	
14				.29			.29	2:45P				1.0				1.0	
15			.17				.17	11:30			1.1					1.1	
16				.18			.18	1:45P				1.0				1.0	
17				.11			.11	3:45P				1.1				1.1	
18			.23				.23	11:00A			1.1					1.1	
19			.22				.22	11:00A			1.0					1.0	
20				.20			.20	3:45P				1.0				1.0	
21				.12			.12	2:00P				1.0				1.0	
22				.23			.23	2:30				0.9				0.9	
23					.24		.24	5:00P					.8			.8	
24					.17		.17	5:00P					.7			.7	
25			.19				.19	9:15A			.9					.9	
26						.21	.21	10:15P						1.1		1.1	
27					.18		.18	5:30P				1.0				1.0	
28				.30			.30	3:00P				1.2				1.2	
29						.17	.17	3:25P					.9			.9	
30				.14			.14	3:45P				.9				.9	
31																	

RECEIVED

DEC 01 2009

If at Any Time the combined filter effluent turbidity exceeds 5 NTU (>5.49), the state must be notified as soon as possible, but not later than the end of the next business day.