

Colorado Department of Public Health and Environment – Water Quality Control Division  
Drinking Water Program – Compliance Assurance and Data Management Unit  
4300 Cherry Creek Drive South, Denver, CO 80246-1530  
Fax 303-758-1398

**MRDL Form 2**  
**Quarterly Reporting Form for Chlorine and Chloramines Maximum Residual Disinfectant**  
**Level Running Annual Average (RAA)**

PWSID #: CO-0207504 SYSTEM NAME: MEADOW MOUNTAIN WATER SUPPLY DATE: May 5<sup>th</sup> 2009  
PREPARED BY: RACHEL BARKWORTH TITLE: Records Coordinator  
SIGNATURE: R Barkworth

			Column A	Column B	Column C
Month	Year	Number of Samples Taken	Monthly Average Chlorine or Chloramines (mg/L)	Quarterly Average Chlorine or Chloramines (mg/L)	Running Annual Average Chlorine or Chloramines (mg/L)
January	20 <u>09</u>	31	0.90		
February	20 <u>09</u>	28	0.91		
March	20 <u>09</u>	31	0.96	Q1 = 0.92	
April	20 <u>08</u>	30	0.96		
May	20 <u>08</u>	31	0.93		
June	20 <u>08</u>	30	0.88	Q2 = 0.92	
July	20 <u>08</u>	31	0.85		
August	20 <u>08</u>	31	0.65		
September	20 <u>08</u>	30	0.95	Q3 = 0.82	
October	20 <u>08</u>	31	0.95		
November	20 <u>08</u>	30	0.95		
December	20 <u>08</u>	31	0.94	Q4 = 0.95	
Running Annual Average =					0.90

**MONITORING RECORDS MUST BE AVAILABLE UPON REQUEST**

**Instructions on Reverse**

This form is available at <http://www.cdphe.state.co.us/wq/drinkingwater/PublicWaterSystemReportingForms.html>