

RECEIVED

JAN 22 2009

## LABORATORY ANALYTICAL REPORT

Customer 20011350  
Meadow Mountain Water  
PO Box 354  
Allenspark, CO 80510  
PWSID: CO 0207504

Invoice Number: 20090016  
Received Date & Time: 1/7/2009 10:10AM  
Arrival Temperature: 7.4°C

Sample Identification: Plant, Raw

Sample Information: Stream or River, Unchlorinated; .32 NTU

Sample Date & Time: 1/7/2009 8:50AM

Sampler: Stephen Tedford

Volume Sampled: 100ml

Sample Type: Grab

Processing Date & Time: 1/7/2009 10:41AM

Analytical Method: 9223B, IDEXX Colilert® with QuantiTray® 2000

Start Date & Time: 1/7/2009 10:41AM

Amount Analyzed: 100ml

Stop Date & Time: 1/8/2009 10:41AM

Additional Start Date & Time: N/A

Dilution factor: N/A

Additional Stop Date & Time: N/A

Analytical Results:

*E. coli* coliform: 0 MPN/100ml

Analyte Reporting Limit: 1.0

This sample was analyzed for the presence of *Escherichia coli* (*E. coli*) by the method outlined in: Standard Methods for the Examination of Water and Wastewater, 20th Edition, 1998, 9223 B, Enzyme Substrate Test. All limitations stated in the method apply.

  
Report Approved By

  
Title

1/24/09  
Date

CH Diagnostic Consulting Service, Inc.  
512 5th Street, Berthoud CO 80513  
PH: (970) 532 2078 FX: (970) 532 3358