

RECEIVED

FEB 20 2009

LABORATORY ANALYTICAL REPORT

Customer 20011350
Meadow Mountain Water
PO Box 354
Allenspark, CO 80510
PWSID: CO 0207504

Invoice Number: 20090117
Received Date & Time: 2/3/2009 11:15AM
Arrival Temperature: 7.0°C

Sample Identification: Plant, Raw	
Sample Information: Stream or River, Unchlorinated; .28 NTU	
Sample Date & Time: 2/3/2009 8:20AM	Sampler: Steve Tedford
Volume Sampled: 100ml	Sample Type: Grab
Processing Date & Time: 2/3/2009 12:03PM	

Analytical Method: 9223B, IDEXX Colilert® with QuantiTray® 2000

Start Date & Time: 2/3/2009 12:03PM Amount Analyzed: 100ml
Stop Date & Time: 2/4/2009 12:03PM

Additional Start Date & Time: N/A
Additional Stop Date & Time: N/A


Dilution factor: N/A

Analytical Results:

E. coli coliform: 0 MPN/100ml

Analyte Reporting Limit: 1.0

This sample was analyzed for the presence of *Escherichia coli* (*E. coli*) by the method outlined in: Standard Methods for the Examination of Water and Wastewater, 20th Edition, 1998, 9223 B, Enzyme Substrate Test. All limitations stated in the method apply.


Report Approved By

Title

Date

CH Diagnostic Consulting Service, Inc.
512 5th Street, Berthoud CO 80513
PH: (970) 532 2078 FX: (970) 532 3358