

## LABORATORY ANALYTICAL REPORT

**Customer** 20011350  
Meadow Mountain Water  
PO Box 354  
Allenspark, CO 80510  
**PWSID:** CO 0207504

**Invoice Number:** 20090421  
**Received Date & Time:** 4/15/2009 12:20PM  
**Arrival Temperature:** 8.6°C

**Sample Identification:** Plant, Raw

**Sample Information:** Stream or River, Unchlorinated; .23 NTU

**Sample Date & Time:** 4/15/2009 9:45AM

**Sampler:** Steve Tedford

**Volume Sampled:** 100ml

**Sample Type:** Grab

**Processing Date & Time:** 4/15/2009 1:28PM

**Analytical Method:** 9223B, IDEXX Colilert® with QuantiTray® 2000

**Start Date & Time:** 4/15/2009 1:28PM

**Amount Analyzed:** 100ml

**Stop Date & Time:** 4/16/2009 1:28PM

**Additional Start Date & Time:** N/A

**Dilution factor:** N/A

**Additional Stop Date & Time:** N/A


### Analytical Results:

*E. coli coliform:* 0 MPN/100ml

**Analyte Reporting Limit:** 1.0

*Coliform bacteria:* 45.5 MPN/100ml

This sample was analyzed for the presence of Escherichia coli (E. coli) by the method outlined in: Standard Methods for the Examination of Water and Wastewater, 20th Edition, 1998, 9223 B, Enzyme Substrate Test. All limitations stated in the method apply.

  
**Report Approved By**

**Title**

**Date**

CH Diagnostic Consulting Service, Inc.  
512 5th Street, Berthoud CO 80513  
PH: (970) 532 2078 FX: (970) 532 3358