

RECEIVED

JUL 21 2009

## LABORATORY ANALYTICAL REPORT

Customer 20011350  
Meadow Mountain Water  
PO Box 354  
Allenspark, CO 80510  
PWSID: CO 0207504

Invoice Number: 20090778  
Received Date & Time: 6/24/2009 9:25AM  
Arrival Temperature: 15.2°C

Sample Identification: Plant, Raw

Sample Information: Stream or River, Unchlorinated; .28 NTU

Sample Date & Time: 6/24/2009 8:05AM

Sampler: Steve Tedford

Volume Sampled: 100ml

Sample Type: Grab

Processing Date & Time: 6/24/2009 12:57PM

Analytical Method: 9223B, IDEXX Colilert® with QuantiTray® 2000

Start Date & Time: 6/24/2009 12:57PM

Amount Analyzed: 100ml

Stop Date & Time: 6/25/2009 12:57PM

Additional Start Date & Time: N/A

Dilution factor: N/A

Additional Stop Date & Time: N/A

Analytical Results:

*E. coli* Coliform: 0 MPN/100ml

Analyte Reporting Limit: 1.0

This sample was analyzed for the presence of *Escherichia coli* (*E. coli*) by the method outlined in: Standard Methods for the Examination of Water and Wastewater, 20th Edition, 1998, 9223 B, Enzyme Substrate Test. All limitations stated in the method apply.

  
Report Approved By  
  
Title Date

CH Diagnostic Consulting Service, Inc.  
512 5th Street, Berthoud CO 80513  
PH: (970) 532 2078 FX: (970) 532 3358