

RECEIVED

NOV 05 2009

LABORATORY ANALYTICAL REPORT

Customer 20011350
Meadow Mountain Water
PO Box 354
Allenspark, CO 80510
PWSID: CO 0207504

Invoice Number: 20091359
Received Date & Time: 10/30/2009 9:45AM
Arrival Temperature: 9.6°C

Sample Identification: Plant, Raw

Sample Information: Stream or River, Unchlorinated; .25 NTU

Sample Date & Time: 10/30/2009 7:00AM

Sampler: unrec.

Volume Sampled: 100ml

Sample Type: Grab

Processing Date & Time: 10/30/2009 11:55AM

Analytical Method: 9223B, IDEXX Colilert® with QuantiTray® 2000

Start Date & Time: 10/30/2009 11:55AM

Amount Analyzed: 100ml

Stop Date & Time: 10/31/2009 11:55AM

Additional Start Date & Time: N/A

Dilution factor: N/A

Additional Stop Date & Time: N/A

Analytical Results:

***E. coli* Coliform:** 0 MPN/100ml

Analyte Reporting Limit: 1.0

This sample was analyzed for the presence of Escherichia coli (*E. coli*) by the method outlined in: Standard Methods for the Examination of Water and Wastewater, 20th Edition, 1998, 9223 B, Enzyme Substrate Test. All limitations stated in the method apply.



Report Approved By

Title

Date

CH Diagnostic Consulting Service, Inc.
512 5th Street, Berthoud CO 80513
PH: (970) 532 2078 FX: (970) 532 3358