

# Laboratory Report

RECEIVED

OCT 21 2009

**Client:**  
**Meadow Mountain Water Company**  
P.O. Box 162  
Allenspark CO 80510  
Attn: Steve Tedford

**Date Sampled:** 7/13/2009 9:00:00 AM  
**Date Received:** 7/14/2009  
**Batch No:** 3520  
**Laboratory ID:** S092441537  
**Matrix:** Solid Grab  
**Sample Name:**

Faucet aerator received with blue-green solids. Client requested a qualitative analysis of the solids.

Analysis	Results	Units	MRL	Method	Analysis Date	Sent Out	Analyst	Laboratory
Metals Scan/General	187	Batch #	1	EPA 200.7	7/17/2009	MAG	<input type="checkbox"/>	

The solids consist of the following metal salts: sodium, copper, calcium, zinc, magnesium, and iron. It most likely is coming from the hardness in the water and corrosion of brass in the faucet itself.

Results Approved by:



Michael Glavanovich, Laboratory Manager

Date Reported: 9/1/2009



Stewart Environmental Consultants, Inc.  
3801 Automation Way, Suite 200 ♦ Fort Collins, CO 80525  
Phone 970-226-5500 ♦ Fax: 970-226-4946