

DBP Form 1 - Total Trihalomethane Analysis Laboratory Report Form										
Section I (to be completed by the Public Water Systems only)					Section II (to be completed by Laboratories only)					
Public Water System Information					Laboratory Information					
PWSID #	CO-0207504				Laboratory Name	Stewart Environmental Consultants, Inc.				
System Name:	Meadow Mountain Water Company				Contact Person:	Michael A. Glavanovich				
Address:	P.O. Box 162, Allenspark, CO 80510				Phone #:	(970) 226-5500				
Contact Person:	Steve Tedford				Comments:					
	Phone #: (303) 747-2066									
System Authorized Signature					Laboratory Authorized Signature					
Title					Title					
Date					Date					
PWS to complete first 3 columns					Laboratories to complete columns 4-6 and 8-11					
Sample Date	Collector	Sample Location Designation #	Date Lab Received	Date Lab Analyzed	Laboratory Sample ID #	Analyte	Analytical Method	µg/L Blank Result	µg/L Lab MDL	µg/L Result
07/13/09	Steve Tedford	Newton	07/13/09	07/23/09	S091940958	Chloroform	524.2	BDL	2.0	32.0
						Bromoform	524.2	BDL	2.0	BDL
						Bromodichloromethane	524.2	BDL	2.0	2.0
						Dibromochloromethane	524.2	BDL	2.0	BDL
						TTHMs				34.0
						Analyte	Analytical Method	µg/L Blank Result	µg/L Lab MDL	µg/L Result
						Chloroform				
						Bromoform				
						Bromodichloromethane				
						Dibromochloromethane				
						TTHMs				
						Analyte	Analytical Method	µg/L Blank Result	µg/L Lab MDL	µg/L Result
						Chloroform				
						Bromoform				
						Bromodichloromethane				
						Dibromochloromethane				
						TTHMs				
						Analyte	Analytical Method	µg/L Blank Result	µg/L Lab MDL	µg/L Result
						Chloroform				
						Bromoform				
						Bromodichloromethane				
						Dibromochloromethane				
						TTHMs				