



Colorado Department
of Public Health
and Environment

Colorado Department of Public Health and Environment
Compliance Assurance & Data Management Unit

REPORTING FORM FOR BACTERIOLOGICAL ANALYSIS

SAMPLER: FILL OUT ONE FORM - FOR EACH INDIVIDUAL SAMPLING POINT

PWSID #: CO0 207504 COUNTY: _____ DATE COLLECTED: 4, 5, 10
SYSTEM/ESTABLISHMENT NAME: Meadow Mountain Water
SYSTEM MAILING ADDRESS: _____

CONTACT PERSON: Steve Tedford Street address/PO Box CITY STATE ZIP
PHONE: ()
SAMPLE COLLECTED BY: Steve Tedford TIME COLLECTED: 130 am pm
WATER TYPE: RAW (No chlorine or other treatment) ☐ CHLORINATED ☒ OTHER TREATMENT ☐

SAMPLE POINT (Address)	CHLORINE RESIDUAL in mg/L	SAMPLE TYPE
<u>FINISHED</u>	<u>.8</u>	<input checked="" type="checkbox"/> Routine <input type="checkbox"/> Repeat <input type="checkbox"/> Special Purpose

For Laboratory Use Only Below This Line
LABORATORY SAMPLE # 20100235 CLIENT NAME or ID# Meadow Mountain Water
LABORATORY NAME: CHDIAGNOSTIC + CONSULTING SERVICE, INC. LAB PHONE # 410 532-2078
DATE RECEIVED IN LABORATORY 4, 5, 10 DATE ANALYZED 4, 7, 10
COMMENTS: NTU = 7.28

PARAMETER	RESULT	UNITS	ANALYSIS DATE	LABORATORY METHOD
Coliform, TOTAL (Verified)		#/100 mL		
Coliform, FECAL/e. Coli (Verified)		#/100 mL		
Coliform, TOTAL (Absent/Present)	<u>ABSENT</u>		<u>4/7/10</u>	<u>Colilert 24</u>
Coliform, FECAL/e. Coli (Absent/Present)				

LABORATORY: Please call Drinking Water Section with any results other than <1 or ABSENT.

NT = Not Tested for compound
TNTC = Too Numerous To Count - Please resample
OD = Outdated - Please resample
<1 = Safe valid sample
Present Coliform / e.Coli / Fecal detected

#/100 ml = Number of colonies per 100 ml of sample
CG = Confluent Growth - Please resample
LA = Lab Accident - Please resample
Absent = Coliform / e.Coli / Fecal not detected

7/20/10 Present 4, 7, 10
Reviewed & Approved by Title Date

MAIL RESULTS TO: CDPHE, WQCD-CADM-B2, 4300 Cherry Creek Drive South, Denver, CO 80246-1530

LABORATORY ANALYTICAL REPORT

Customer 20011350
Meadow Mountain Water
PO Box 354
Allenspark, CO 80510
PWSID: CO 0207504

Invoice Number: 20100235
Received Date & Time: 4/5/2010 10:00AM
Arrival Temperature: 8.8°C

Sample Identification: Finished

Sample Information: Stream or River, Chlorinated; .28 NTU

Sample Date & Time: 4/5/2010 7:30AM

Sampler: Steve Tedford

Volume Sampled: 100ml

Sample Type: Grab

Processing Date & Time: 4/6/2010 11:10AM

Analytical Method: 9223B, IDEXX Colilert® with QuantiTray® 2000

Start Date & Time: 4/6/2010 11:10AM

Amount Analyzed: 100ml

Stop Date & Time: 4/7/2010 11:10AM

Additional Start Date & Time: N/A

Dilution factor: N/A

Additional Stop Date & Time: N/A


Analytical Results:

Analyte Reporting Limit: 1.0

Coliform bacteria: ABSENT

Chlorine Residual: 0.8

This sample was analyzed for the presence of Escherichia coli (E. coli) by the method outlined in: Standard Methods for the Examination of Water and Wastewater, 20th Edition, 1998, 9223 B, Enzyme Substrate Test. All limitations stated in the method apply.


Report Approved By


Title

Date

CH Diagnostic Consulting Service, Inc.
512 5th Street, Berthoud CO 80513
PH: (970) 532 2078 FX: (970) 532 3358