



Colorado Department
of Public Health
and Environment

Colorado Department of Public Health and Environment
Compliance Assurance & Data Management Unit

REPORTING FORM FOR BACTERIOLOGICAL ANALYSIS

SAMPLER: FILL OUT ONE FORM - FOR EACH INDIVIDUAL SAMPLING POINT

PWSID #: CO0 207504 COUNTY: _____ DATE COLLECTED: 10/1/2010
SYSTEM/ESTABLISHMENT NAME: Meadow Mountain Water
SYSTEM MAILING ADDRESS: P.O. Box 354 Allenspark, CO 80510
CONTACT PERSON: Steve Tedford CITY _____ STATE _____ ZIP _____
PHONE: () _____
SAMPLE COLLECTED BY: Steve Tedford TIME COLLECTED: 730 am/pm
WATER TYPE: RAW (No chlorine or other treatment) ☐ CHLORINATED ☒ OTHER TREATMENT ☐

SAMPLE POINT (Address)	CHLORINE RESIDUAL in mg/L	SAMPLE TYPE
<u>FINISHED</u>	<u>1.0</u>	<input checked="" type="checkbox"/> Routine <input type="checkbox"/> Repeat <input type="checkbox"/> Special Purpose

For Laboratory Use Only Below This Line
LABORATORY SAMPLE # 20100771 CLIENT NAME or ID# _____
LABORATORY NAME: CDIAGNOSTIC LAB PHONE # 970.532.2078
DATE RECEIVED IN LABORATORY 10/1/2010 DATE ANALYZED 10/2/2010
COMMENTS: _____

PARAMETER	RESULT	UNITS	ANALYSIS DATE	LABORATORY METHOD
Coliform, TOTAL (Verified)		#/100 mL		
Coliform, FECAL/e. Coli (Verified)		#/100 mL		
Coliform, TOTAL (Absent/Present)	<u>Absent</u>		<u>10/2/10</u>	<u>ColiTest 24</u>
Coliform, FECAL/e. Coli (Absent/Present)				

LABORATORY: Please call Drinking Water Section with any results other than < 1 or ABSENT.

NT = Not Tested for compound

TNTC = Too Numerous To Count - Please resample

OD = Outdated - Please resample

<1 = Safe valid sample

Present Coliform / e.Coli /Fecal detected

#/100 ml = Number of colonies per 100 ml of sample

CG = Confluent Growth - Please resample

LA = Lab Accident - Please resample

Absent = Coliform / e.Coli /Fecal not detected

Steve Tedford Present 10/15/10
Reviewed & Approved by Title Date

MAIL RESULTS TO: CDPHE, WQCD-CADM-B2, 4300 Cherry Creek Drive South, Denver, CO 80246-1530

LABORATORY ANALYTICAL REPORT

Customer 20011350
Meadow Mountain Water
PO Box 354
Allenspark, CO 80510
PWSID: CO 0207504

Invoice Number: 20100771
Received Date & Time: 10/1/2010 9:00AM
Arrival Temperature: 18°C

Sample Identification: Finished

Sample Information: Chlorinated; unrec. NTU

Sample Date & Time: 10/1/2010 7:30AM

Sampler: Steve Tedford

Volume Sampled: 100ml

Sample Type: Grab

Processing Date & Time: 10/1/2010 11:20AM

Analytical Method: 9223B, IDEXX Colilert® with QuantiTray® 2000

Start Date & Time: 10/1/2010 11:20AM

Amount Analyzed: 100ml

Stop Date & Time: 10/2/2010 11:20AM

Additional Start Date & Time: N/A

Dilution factor: N/A

Additional Stop Date & Time: N/A




Analytical Results:

Analyte Reporting Limit: 1.0

Coliform bacteria: ABSENT

Chlorine Residual: 1

This sample was analyzed for the presence of Escherichia coli (E. coli) by the method outlined in: Standard Methods for the Examination of Water and Wastewater, 20th Edition, 1998, 9223 B, Enzyme Substrate Test. All limitations stated in the method apply.


Report Approved By
 
Title **Date**