

COLORADO DEPARTMENT OF PUBLIC HEALTH AND ENVIRONMENT

MONTHLY OPERATIONAL REPORT - Data Sheet

SLOW SAND, DIATOMACEOUS EARTH & OTHER FILTRATION

Required Number of Turbidity Readings Per Day: 1

DAY	TURBIDITY (NTU)								RESIDUAL DISINFECTANT (mg/L)								12. COMMENTS	RECEIVED OCT 07 2010
	☐ Continuous Sampling				☒ Grab Sampling				☐ Continuous Sampling				☒ Grab Sampling					
	12 to 4	4 to 8	8 to 12	12 to 4	4 to 8	8 to 12	HIGHEST TURBIDITY READING	TIME TURBIDITY READ	12 to 4	4 to 8	8 to 12	12 to 4	4 to 8	8 to 12	LOWEST RESIDUAL READING			
1							.30	4:00P								1.0		
2			.24				.24	8:30A								1.0		
3			.23				.23	11:30A								1.0		
4			.25				.25	3:45P								1.0		
5			.38				.38	7:30P								1.0		
6			.32				.32	11:30P								1.0		
7			.34				.34	1:45A								1.0		
8			.20				.20	3:30P								1.0		
9			.19				.19	11:30A								.8		
10			.25				.25	3:30P								1.2		
11			.19				.19	5:00P								1.1		
12			.18				.18	12:20								1.0		
13			.15				.15	5:00P								1.0		
14			.17				.17	5:15P								1.0		
15			.28				.28	3:45P								1.0		
16			.21				.21	5:00P								1.0		
17			.19				.19	7:45P								1.0		
18			.20				.20	1:00P								1.0		
19			.22				.22	7:00P								1.0		
20			.19				.19	7:00P								1.0		
21			.26				.26	5:00P								1.0		
22			.27				.27	3:30P								1.0		
23			.25				.25	11:30A								.9		
24			.21				.21	11:30A								.9		
25			.19				.19	5:30P								1.0		
26			.28				.28	3:45P								.8		
27			.19				.19	5:00P								1.0		
28			.17				.17	3:50P								1.0		
29			.25				.25	2:00P								1.0		
30			.18				.18	11:00A								1.0		
31																		

***If at Any Time the combined filter effluent turbidity exceeds 5 NTU (>5.49), the state must be notified as soon as possible, but not later than the end of the next business day. ***

Meadow Mountain
Water Supply CO
PWSID #: 000201504