

COLORADO DEPARTMENT OF PUBLIC HEALTH AND ENVIRONMENT
MONTHLY OPERATIONAL REPORT - Data Sheet

Meadow Mountain
WS
PWSID #: *00-0201504*

SLOW SAND, DIATOMACEOUS EARTH & OTHER FILTRATION

Required Number of Turbidity Readings Per Day: 1

DAY	TURBIDITY (NTU)								RESIDUAL DISINFECTANT (mg/L)								12. COMMENTS	RECEIVED DEC 05 2010
	☐ Continuous Sampling ☒ Grab Sampling								☐ Continuous Sampling ☒ Grab Sampling									
	12 to 4	4 to 8	8 to 12	12 to 4	4 to 8	8 to 12	HIGHEST TURBIDITY READING	TIME TURBIDITY READ	12 to 4	4 to 8	8 to 2	12 to 4	4 to 8	8 to 12	LOWEST RESIDUAL READING			
1							.19	5:15P							1.0			
2							.21	8:15A			1.0				1.0			
3							.23	4:10P					.8		.8			
4							.26	4:30P					.8		.8			
5							.18	2:00P					1.0		1.0			
6							.30	3:00P					1.0		1.0			
7							.21	1:15P					1.0		1.0P			
8							.34	4:30P					1.0		1.0			
9							.26	3:30P					1.2		1.2			
10							.23	11:15A			.9				.9			
11							.21	11:00A			1.0				1.0			
12							.17	3:00P					1.0		1.0			
13							.15	3:45P			.8		1.0		1.0			
14							.22	10:30A			1.0				1.0			
15							.04	5:15P					.9		.9			
16							.28	1:45P			.9				.9			
17							.24	12:20P			.9				.9			
18							.25	11:00A			.9				.9			
19							.19	3:30P			1.2				1.2			
20							.21	3:45P			1.1				1.1			
21							.28	12:20P			1.0				1.0			
22							.26	5:35P					1.0		1.0			
23							.27	1:30P			1.0				1.0			
24							.30	9:30A			1.0				1.0			
25							.21	1:10P					0.8		0.8			
26							.26	10:40			0.8				0.8			
27							.21	7:30P			.8				.8			
28							.24	3:55			.7				.7			
29							.23	11:30A			.5				.5			
30							.54	4:00P					.5		.5			
31																		

***If at Any Time the combined filter effluent turbidity exceeds 5 NTU (>5.49), the state must be notified as soon as possible, but not later than the end of the next business day. ***