

STATE OF COLORADO

Bill Ritter, Jr., Governor
Martha E. Rudolph, Executive Director

Dedicated to protecting and improving the health and environment of the people of Colorado

4300 Cherry Creek Dr. S.
Denver, Colorado 80246-1530
Phone (303) 692-2000
TDD Line (303) 691-7700
Located in Glendale, Colorado

Laboratory Services Division
8100 Lowry Blvd.
Denver, Colorado 80230-6928
(303) 692-3090

<http://www.cdphe.state.co.us>



Colorado Department
of Public Health
and Environment

March 30, 2010

RACHEL BARKWORTH
MEADOW MOUNTAIN WS
PWSID# CO0207504
PO BOX 354
ALLENSPARK, CO 80510

RE: Long Term 2 Enhanced Surface Water Treatment Rule (LT2ESWTR)
Bin Classification

Dear Ms. BARKWORTH:

Thank you for completing the initial round of source water monitoring for the LT2ESWTR. The Water Quality Control Division (the "Division") has received adequate source water *E. coli* monitoring data to comply with the initial source water monitoring requirements.

This data was used to determine the bin classification for these facilities by using the twelve (12) month mean. The mean *E. coli* values and bin classifications for each facility are as follows:

Facility	Trigger Limit	Mean <i>E. coli</i> Value	Bin Classification	Crypto Monitoring Required
CRS001	100 <i>E.coli</i> /100mL	0.73 <i>E.coli</i> /100mL	Bin 1	NO

This notification will function as the System's Bin Classification as required by Section 7.4.9 of the *Colorado Primary Drinking Water Regulations* (the "Regulations").

In accordance with the Regulations, Section 7.4.10(a), no additional treatment is required for *Cryptosporidium* at facilities that classify in Bin 1.

A second round of source water monitoring is required as part of the LT2ESWTR beginning in 2017. The System's bin classification may change based on the results of the second round of monitoring. Grandfathering data will not be accepted for the second round of monitoring.

If you have questions regarding this letter or methods to comply with the additional sampling requirements, please contact me by sending an e-mail to julie.conroy@state.co.us or calling 303-692-3405.

Sincerely,

A handwritten signature in cursive script, appearing to read "Julie Conroy".

Julie Conroy
Early Implementation Specialist
Drinking Water Compliance Assurance Unit
Water Quality Control Division

cc: Drinking Water File, PWSID# CO0207504