

Laboratory Report

Client:
Meadow Mountain Water Company
P.O. Box 162
Allenspark CO 80510
Attn: Steve Tedford

Date Sampled: 8/2/2010 7:10:00 AM
Date Received: 8/2/2010
Batch No: 10213
Laboratory ID: S102141631
Matrix: Drinking Water Grab
Sample Name: MM

Project # 1115-021

Analysis	Results	Units	MRL	Method	Analysis Date	Analyst	Sent Out	Laboratory
. Haloacetic acids (552.2)	41.6	Batch #	1	EPA 552.2	8/10/2010		☒	Accutest Mountain States
. Trihalomethanes	223	Batch #	0	EPA 524.2	8/11/2010	WVS	☐	
.524 Bromodichloromethane	<0.002	ppm	0.002	EPA 524.2	8/11/2010	WVS	☐	
.524 Bromoform	<0.002	ppm	0.002	EPA 524.2	8/11/2010	WVS	☐	
.524 Chlorodibromomethane	<0.002	ppm	0.002	EPA 524.2	8/11/2010	WVS	☐	
.524 Chloroform	0.034	ppm	0.002	EPA 524.2	8/11/2010	WVS	☐	
Total Coliform	0	0=A / 1=P	0	ReadyCult	8/2/2010	LES	☐	

Sample tested absent for both total coliforms and E. coli

Results Approved by:



Michael Glavanovich, Laboratory Manager

Date Reported: 9/17/2010



Stewart Environmental Consultants LLC

3801 Automation Way, Suite 200 ♦ Fort Collins, CO 80525
Phone 970-226-5500 ♦ Fax:970-226-4946