

Colorado Department of Public Health and Environment Compliance Assurance & Data Management Unit

RECEIVED
APR 1 1 2011

REPORTING FORM FOR BACTERIOLOGICAL ANALYSIS

SAMPLER: FILL OUT ONE FORM - FOR \underline{EACH} INDIVIDUAL SAMPLING POINT

SYSTEM/ESTABLISHMENT NAME SYSTEM MAILING ADDRESS: CONTACT PERSON: SAMPLE COLLECTED BY:	DUNTY: BY CHARLES AND BOX CHARLES AND	W HC 354 Advol Ford	DATE OF LOTTING TIME COLLECTION	COLLECTED: 1 A + C C STATE STATE OTHER TREATI	2IP MENT
SAMPLE POINT (Address) CHLORINE RESIDUAL in mg/L SAMPLE TYPE					
FINISHED"			Repeat		Routine Repeat Special Purpose
LABORATORY SAMPLE # 3010144 CLIENT NAME or ID# MEADUN HOUNTAUN WOLK LABORATORY NAME: 4 D10000570 LAB PHONE # 670,530 2078 DATE RECEIVED IN LABORATORY 4,5,1,1 DATE ANALYZED 4,6,1,1 (28)					
PARAMETER	RESULT	UNITS	ANALYSIS DATE	LABORATORY	METHOD
Coliform, TOTAL (Verified)		#/100 mL			
Coliform, FECAL/e. Coli (Verified)		#/100 mL		-	
Coliform, TOTAL (Absent/Present)	Albsent		4/6/11 1145	Colilert	24
Coliform, FECAL/e. Coli (Absent/Present)					
LABORATORY: Please call Drinking Water Section with any results other than < 1 or ABSENT. NT = Not Tested for compound #/100 ml = Number of colonies per 100 ml of sample TNTC = Too Numerous To Count - Please resample					

MAIL RESULTS TO: CDPHE, WQCD-CADM-B2, 4300 Cherry Creek Drive South, Denver, CO 80246-1530

LABORATORY ANALYTICAL REPORT

Customer 20011350

Meadow Mountain Water

PO Box 354

Allenspark, CO 80510 PWSID: CO 0207504 Invoice Number: 20110144

Received Date & Time: 4/5/2011 10:15AM

Arrival Temperature: 2.3°C

Sample Identification: Finished

Sample Information: Chlorinated; unrec. NTU

Sample Date & Time: 4/5/2011 9:30AM Sampler: Steve Tedford

Volume Sampled: 100ml Sample Type: Grab

Processing Date & Time: 4/5/2011 11:45AM

Analytical Method: 9223B, IDEXX Colllert® with QuantiTray® 2000

Start Date & Time: 4/5/2011 11:45AM

Amount Analyzed: 100ml

Stop Date & Time: 4/6/2011 11:45AM

Additional Start Date & Time: N/A

Dilution factor: N/A

Additional Stop Date & Time: N/A

Analytical Results:

Analyte Reporting Limit: 1.0

Coliform bacteria: ABSENT

Chlorine Residual:

0.9

This sample was analyzed for the presence of Escherichia coli (E. coli) by the method outlined in: Standard Methods for the Examination of Water and Wastewater, 20th Edition, 1998, 9223 B, Enzyme Substrate Test. All limitations stated in the method apply.

CH Diagnostic Consulting Service, Inc. 512 5th Street, Berthoud CO 80513 PH: (970) 532 2078 FX: (970) 532 3358