

Meadow Mountain
W/S

COLORADO DEPARTMENT OF PUBLIC HEALTH AND ENVIRONMENT
MONTHLY OPERATIONAL REPORT - Data Sheet
SLOW SAND, DIATOMACEOUS EARTH & OTHER FILTRATION

December
2011

Number of Turbidity Readings Per Day:

PWSID #: CO-0201504

TURBIDITY (NTU)	RESIDUAL DISINFECTANT (mg/L)												12. COMMENTS	
	□ Continuous Sampling						□ Grab Sampling							
	TIME TURBIDITY READ						ENTRY POINT TO DISTRIBUTION							
12 to 4	4 to 8	8 to 12	12 to 4	4 to 8	8 to 12	HIGHEST TURBIDITY READING	12 to 4	4 to 8	8 to 12	12 to 4	4 to 8	8 to 12	LOWEST RESIDUAL READING	
1	.16	.21	.19	.16	.16	1.36	.16	.21	.19	.19	.19	.19	.19	
2	.20	.20	.19	.19	.19	2.36	.21	.19	.19	.19	.19	.19	.19	
3	.16	.16	.19	.19	.19	1.36	.19	.19	.19	.19	.19	.19	.19	
4	.16	.16	.16	.16	.16	1.36	.16	.16	.16	.16	.16	.16	.16	
5	.16	.16	.16	.16	.16	1.36	.16	.16	.16	.16	.16	.16	.16	
6	.32	.24	.24	.24	.24	1.36	.32	.24	.24	.24	.24	.24	.24	
7	.24	.19	.19	.19	.19	1.36	.24	.19	.19	.19	.19	.19	.19	
8	.27	.27	.27	.27	.27	1.36	.27	.27	.27	.27	.27	.27	.27	
9	.21	.21	.21	.21	.21	1.36	.21	.21	.21	.21	.21	.21	.21	
10	.21	.21	.21	.21	.21	1.36	.21	.21	.21	.21	.21	.21	.21	
11	.28	.28	.28	.28	.28	1.36	.28	.28	.28	.28	.28	.28	.28	
12	.29	.29	.29	.29	.29	1.36	.29	.29	.29	.29	.29	.29	.29	
13	.16	.16	.16	.16	.16	2.36	.16	.16	.16	.16	.16	.16	.16	
14	.20	.20	.20	.20	.20	3.36	.20	.20	.20	.20	.20	.20	.20	
15	.32	.32	.32	.32	.32	3.36	.32	.32	.32	.32	.32	.32	.32	
16	.28	.28	.28	.28	.28	2.36	.28	.28	.28	.28	.28	.28	.28	
17	.21	.21	.21	.21	.21	3.36	.21	.21	.21	.21	.21	.21	.21	
18	.20	.20	.20	.20	.20	9:30A	.20	.20	.20	.20	.20	.20	.20	
19	.26	.26	.26	.26	.26	3:26P	.26	.26	.26	.26	.26	.26	.26	
20	.16	.16	.16	.16	.16	3:58P	.16	.16	.16	.16	.16	.16	.16	
21	.24	.24	.24	.24	.24	1:30P	.24	.24	.24	.24	.24	.24	.24	
22	.26	.26	.26	.26	.26	4:45P	.26	.26	.26	.26	.26	.26	.26	
23	.18	.18	.18	.18	.18	2:15P	.18	.18	.18	.18	.18	.18	.18	
24	.21	.21	.21	.21	.21	9:30P	.21	.21	.21	.21	.21	.21	.21	
25	.16	.16	.16	.16	.16	11:45P	.16	.16	.16	.16	.16	.16	.16	
26	.20	.20	.20	.20	.20	3:26	.20	.20	.20	.20	.20	.20	.20	
27	.27	.27	.27	.27	.27	3:30	.27	.27	.27	.27	.27	.27	.27	
28	.20	.20	.20	.20	.20	4:30	.20	.20	.20	.20	.20	.20	.20	
29	.16	.16	.16	.16	.16	7:00A	.16	.16	.16	.16	.16	.16	.16	
30	.21	.21	.21	.21	.21	5:00A	.21	.21	.21	.21	.21	.21	.21	
31	.16	.16	.16	.16	.16	10:30P	.16	.16	.16	.16	.16	.16	.16	

Any Time the combined filter effluent turbidity exceeds 5 NTU (>5.49), the state must be notified as soon as possible, but not later than the end of the next business day. **