



Colorado Department
of Public Health
and Environment

Colorado Department of Public Health and Environment
Compliance Assurance & Data Management Unit

REPORTING FORM FOR BACTERIOLOGICAL ANALYSIS

SAMPLER: FILL OUT ONE FORM - FOR EACH INDIVIDUAL SAMPLING POINT

PWSID #: COO _____ COUNTY: _____ DATE COLLECTED: 5, 7, 12
SYSTEM/ESTABLISHMENT NAME: Meadow Mountain
SYSTEM MAILING ADDRESS: P.O. Box 354 Allenspark, CO 80510
CONTACT PERSON: Steve Tedford CITY _____ STATE _____ ZIP _____
PHONE: (970) 532-2078
SAMPLE COLLECTED BY: Steve Tedford TIME COLLECTED: 7:15 am/pm
WATER TYPE: RAW (No chlorine or other treatment) ☐ CHLORINATED ☒ OTHER TREATMENT ☐

SAMPLE POINT (Address)	CHLORINE RESIDUAL in mg/L	SAMPLE TYPE
<u>FINISHED, BIRREL</u>	<u>0.9</u>	<input checked="" type="checkbox"/> Routine <input type="checkbox"/> Repeat <input type="checkbox"/> Special Purpose

For Laboratory Use Only Below This Line
LABORATORY SAMPLE # 20120177 CLIENT NAME or ID# Meadow Mountain
LABORATORY NAME: CH DIAGNOSTIC LAB PHONE # (970) 532-2078
DATE RECEIVED IN LABORATORY 5/7/12 DATE ANALYZED 5/8/12
COMMENTS: _____

PARAMETER	RESULT	UNITS	ANALYSIS DATE	LABORATORY METHOD
Coliform, TOTAL (Verified)		#/100 mL		
Coliform, FECAL/e. Coli (Verified)		#/100 mL		
Coliform, TOTAL (Absent/Present)	<u>ABSENT</u>		<u>5/8/12/102</u>	<u>24 Coli test</u>
Coliform, FECAL/e. Coli (Absent/Present)				

LABORATORY: Please call Drinking Water Section with any results other than <1 or ABSENT.

NT = Not Tested for compound

TNTC = Too Numerous To Count - Please resample

OD = Outdated - Please resample

<1 = Safe valid sample

Present Coliform / e.Coli / Fecal detected

#/100 ml = Number of colonies per 100 ml of sample

CG = Confluent Growth - Please resample

LA = Lab Accident - Please resample

Absent = Coliform / e.Coli / Fecal not detected

Reviewed & Approved by: T. Buehler Title: Pres. Dir. Date: 6, 9, 12

LABORATORY ANALYTICAL REPORT

Customer 20011350
Meadow Mountain Water
PO Box 354
Allenspark, CO 80510
PWSID: CO 0207504

Invoice Number: 20120177
Received Date & Time: 5/7/2012 10:00AM
Arrival Temperature: 18.6°C

Sample Identification: Finished, Birrel	
Sample Information: Chlorinated; unrec. NTU	
Sample Date & Time: 5/7/2012 7:15AM	Sampler: Steve Tedford
Volume Sampled: 100ml	Sample Type: Grab
Processing Date & Time: 5/7/2012 10:20AM	

Analytical Method: 9223B, IDEXX Colilert® with QuantiTray® 2000

Start Date & Time: 5/7/2012 10:20AM
Stop Date & Time: 5/8/2012 10:20AM

Amount Analyzed: 100ml

Additional Start Date & Time: N/A
Additional Stop Date & Time: N/A

Dilution factor: N/A

Analytical Results:

Analyte Reporting Limit: 1.0

Coliform bacteria: ABSENT

Chlorine Residual: 0.9

This sample was analyzed for the presence of Escherichia coli (E. coli) by the method outlined in: Standard Methods for the Examination of Water and Wastewater, 20th Edition, 1998, 9223 B, Enzyme Substrate Test. All limitations stated in the method apply.


Report Approved By

Title

Date