



Colorado Department  
of Public Health  
and Environment

Colorado Department of Public Health and Environment  
Compliance Assurance & Data Management Unit

REPORTING FORM FOR BACTERIOLOGICAL ANALYSIS

SAMPLER: FILL OUT ONE FORM - FOR EACH INDIVIDUAL SAMPLING POINT

PWSID #: CO0 207504 COUNTY: \_\_\_\_\_ DATE COLLECTED: 8/7/12  
SYSTEM/ESTABLISHMENT NAME: Meadow Mountain  
SYSTEM MAILING ADDRESS: P.O. Box 354 Allenspark, CO 80510  
CONTACT PERSON: Steve Tedford PHONE: ( ) \_\_\_\_\_  
SAMPLE COLLECTED BY: Steve Tedford TIME COLLECTED: \_\_\_\_\_ am/pm  
WATER TYPE: RAW (No chlorine or other treatment) ☐ CHLORINATED ☒ OTHER TREATMENT ☐

SAMPLE POINT (Address)	CHLORINE RESIDUAL in mg/L	SAMPLE TYPE
<u>FINISHED</u>	<u>1.1</u>	<input checked="" type="checkbox"/> Routine <input type="checkbox"/> Repeat <input type="checkbox"/> Special Purpose

For Laboratory Use Only Below This Line  
LABORATORY SAMPLE # 20120397 CLIENT NAME or ID# Meadow Mountain Water  
LABORATORY NAME: CHD DIAGNOSTIC LAB PHONE # 970 532 2078  
DATE RECEIVED IN LABORATORY 8/7/12 DATE ANALYZED 8/8/12  
COMMENTS: \_\_\_\_\_

PARAMETER	RESULT	UNITS	ANALYSIS DATE	LABORATORY METHOD
Coliform, TOTAL (Verified)		#/100 mL		
Coliform, FECAL/e. Coli (Verified)		#/100 mL		
Coliform, TOTAL (Absent/Present)	<u>Absent</u>		<u>8/8/12 11am</u>	<u>24 Coli test</u>
Coliform, FECAL/e. Coli (Absent/Present)				

LABORATORY: Please call Drinking Water Section with any results other than <1 or ABSENT.

NT = Not Tested for compound

TNTC = Too Numerous To Count - Please resample

OD = Outdated - Please resample

<1 = Safe valid sample

Present Coliform / e. Coli / Fecal detected

#/100 ml = Number of colonies per 100 ml of sample

CG = Confluent Growth - Please resample

LA = Lab Accident - Please resample

Absent = Coliform / e. Coli / Fecal not detected

TSN Y S Pres. Def 8/16/12  
Reviewed & Approved by Title Date

MAIL RESULTS TO: CDPHE, WQCD-CADM-B2, 4300 Cherry Creek Drive South, Denver, CO 80246-1530

## LABORATORY ANALYTICAL REPORT

**Customer** 20011350  
Meadow Mountain Water  
PO Box 354  
Allenspark, CO 80510  
**PWSID:** CO 0207504

**Invoice Number:** 20120397  
**Received Date & Time:** 8/7/2012 10:20AM  
**Arrival Temperature:** 21.2°C

<b>Sample Identification:</b> Finished	
<b>Sample Information:</b> Chlorinated; unrec. NTU	
<b>Sample Date &amp; Time:</b> 8/7/2012 7:45AM	<b>Sampler:</b> Steve Tedford
<b>Volume Sampled:</b> 100ml	<b>Sample Type:</b> Grab
<b>Processing Date &amp; Time:</b> 8/7/2012 11:00AM	

**Analytical Method:** 9223B, IDEXX Colilert® with QuantiTray® 2000

**Start Date & Time:** 8/7/2012 11:00AM      **Amount Analyzed:** 100ml  
**Stop Date & Time:** 8/8/2012 11:00AM

**Additional Start Date & Time:** N/A      **Dilution factor:** N/A  
**Additional Stop Date & Time:** N/A



### Analytical Results:

**Analyte Reporting Limit:** 1.0

**Coliform bacteria:** ABSENT

**Chlorine Residual:** 1.1

This sample was analyzed for the presence of Escherichia coli (E. coli) by the method outlined in: Standard Methods for the Examination of Water and Wastewater, 20th Edition, 1998, 9223 B, Enzyme Substrate Test. All limitations stated in the method apply.

  
\_\_\_\_\_  
**Report Approved By**  
 8/16/12  
\_\_\_\_\_  
**Title**                      **Date**