



Colorado Department
of Public Health
and Environment

Colorado Department of Public Health and Environment
Compliance Assurance & Data Management Unit

REPORTING FORM FOR BACTERIOLOGICAL ANALYSIS

SAMPLER: FILL OUT ONE FORM - FOR EACH INDIVIDUAL SAMPLING POINT

PWSID #: CO0 207504 COUNTY: _____ DATE COLLECTED: 12/6/12
SYSTEM/ESTABLISHMENT NAME: Meadow Mountain Water
SYSTEM MAILING ADDRESS: P.O. Box 354 Allenspark, CO 80510
CONTACT PERSON: Steve Tedford STREET ADDRESS/PO BOX: _____ CITY: _____ STATE: _____ ZIP: _____
PHONE: () _____
SAMPLE COLLECTED BY: Steve Tedford TIME COLLECTED: 800 am/pm
WATER TYPE: RAW (No chlorine or other treatment) ☐ CHLORINATED ☐ OTHER TREATMENT ☐

SAMPLE POINT (Address)	CHLORINE RESIDUAL in mg/L	SAMPLE TYPE
<u>FINISHED</u>	<u>1.1</u>	<input checked="" type="checkbox"/> Routine <input type="checkbox"/> Repeat <input type="checkbox"/> Special Purpose

For Laboratory Use Only Below This Line
LABORATORY SAMPLE # 20750631 CLIENT NAME or ID# Meadow Mountain
LABORATORY NAME: CH Diagnostic LAB PHONE # 970 532-2078
DATE RECEIVED IN LABORATORY 12/6/12 DATE ANALYZED 12/7/12
COMMENTS: _____

PARAMETER	RESULT	UNITS	ANALYSIS DATE	LABORATORY METHOD
Coliform, TOTAL (Verified)		#/100 mL		
Coliform, FECAL/e. Coli (Verified)		#/100 mL		
Coliform, TOTAL (Absent/Present)	<u>Absent</u>		<u>12/7/12 1034</u>	<u>24 Coli test</u>
Coliform, FECAL/e. Coli (Absent/Present)				

LABORATORY: Please call Drinking Water Section with any results other than <1 or ABSENT.

NT = Not Tested for compound

TNTC = Too Numerous To Count - Please resample

OD = Outdated - Please resample

<1 = Safe valid sample

P = Present Coliform / e. Coli / Fecal detected

#/100 ml = Number of colonies per 100 ml of sample

CG = Confluent Growth - Please resample

LA = Lab. Accident - Please resample

Absent = Coliform / e. Coli / Fecal not detected

T. J. E. Prudent 12/13/12
Reviewed & Approved by _____ Title _____ Date _____

LABORATORY ANALYTICAL REPORT

Customer 20011350
Meadow Mountain Water
PO Box 354
Allenspark, CO 80510
PWSID: CO 0207504

Invoice Number: 20120631
Received Date & Time: 12/6/2012 10:20AM
Arrival Temperature: 14.4°C

Sample Identification: Finished

Sample Information: Chlorinated; unrec. NTU

Sample Date & Time: 12/6/2012 8:00AM

Sampler: Steve Tedford

Volume Sampled: 100ml

Sample Type: Grab

Processing Date & Time: 12/6/2012 10:34AM

Analytical Method: 9223B, IDEXX Colilert® with QuantiTray® 2000

Start Date & Time: 12/6/2012 10:34AM

Amount Analyzed: 100ml

Stop Date & Time: 12/7/2012 10:34AM

Additional Start Date & Time: N/A

Dilution factor: N/A

Additional Stop Date & Time: N/A

Analytical Results:

Analyte Reporting Limit: 1.0

Coliform bacteria: ABSENT

Chlorine Residual: 1.1

This sample was analyzed for the presence of Escherichia coli (E. coli) by the method outlined in: Standard Methods for the Examination of Water and Wastewater, 20th Edition, 1998, 9223 B, Enzyme Substrate Test. All limitations stated in the method apply.



Report Approved By

President 12/12/12
Title Date