

January 2012

COLORADO DEPARTMENT OF PUBLIC HEALTH AND ENVIRONMENT
MONTHLY OPERATIONAL REPORT - Data Sheet
SLOW SAND, DIATOMACEOUS EARTH & OTHER FILTRATION

Meadow Mountain WS

Aired Number of Turbidity Readings Per Day: 1

PWSID #: 00-0207504

TURBIDITY (NTU)								RESIDUAL DISINFECTANT (mg/L)								RECEIVED FEB 05 2012 12. COMMENTS	
☐ Continuous Sampling ☒ Grab Sampling								☐ Continuous Sampling ☒ Grab Sampling									
12 to 4	4 to 8	8 to 12	12 to 4	4 to 8	8 to 12	HIGHEST TURBIDITY READING	TIME TURBIDITY READ	ENTRY POINT TO DISTRIBUTION						LOWEST RESIDUAL READING			
								12 to 4	4 to 8	8 to 2	12 to 4	4 to 8	8 to 12				
1			.20			.20	1:00P				.9			.9			
2			.25			.25	1:30P				.9			.9			
3			.28			.28	3:00P				.8			.8			
4				.21		.21	4:30P					.9		.9			
5				.24		.24	4:10P					.9		.9			
6			.30			.30	3:30P				1.1			1.1			
7			.26			.26	2:30P				1.1			1.1			
8			.21			.21	3:30P				1.1			1.1			
9				.24		.24	5:00P					.9		.9			
10				.21		.21	3:30P					.9		.9			
11				.19		.19	3:30P					.9		.9			
12				.20		.20	4:15P					.8		.8			
13				.18		.18	3:00P					.9		.9			
14				.21		.21	2:30P					.9		.9			
15				.16		.16	5:15P					.9		.9			
16			.21			.21	11:00A			.9				.9			
17			.20			.20	2:30P				.8			.8			
18			.17			.17	3:30P				.9			.9			
19			.19			.19	1:30P				.7			.9			
20			.16			.16	10:30A			.9				.9			
21			.19			.19	3:15P				.9			.9			
22			.21			.21	2:45				.4			.4			
23			.16			.16	12:45P				.7			.7			
24				.19		.19	4:05P					.9		.9			
25				.16		.16	4:30P					.9		.9			
26				.21		.21	4:30P					.9		.9			
27			.18			.18	2:00P				.9			.9			
28			.28			.28	10:00A			.9				.9			
29			.20			.20	11:30A			1.0				1.0			
30			.25			.25	10:45A			1.0				1.0			
31			.23			.23	10:30A			1.0				1.0			

Any Time the combined filter effluent turbidity exceeds 5 NTU (>5.49), the state must be notified as soon as possible, but not later than the end of the next business day. ***