

COLORADO DEPARTMENT OF PUBLIC HEALTH AND ENVIRONMENT
 MONTHLY OPERATIONAL REPORT - Data Sheet
 SLOW SAND, DIATOMACEOUS EARTH & OTHER FILTRATION

March 2012

Madison Mountain WS

Aired Number of Turbidity Readings Per Day: 1

PWSID #: 00-0201504

TURBIDITY (NTU)						RESIDUAL DISINFECTANT (mg/L)						RECEIVED APR 06 2012 12. COMMENTS		
☐ Continuous Sampling ☒ Grab Sampling						☐ Continuous Sampling ☒ Grab Sampling								
12 to 4	4 to 8	8 to 12	12 to 4	4 to 8	8 to 12	HIGHEST TURBIDITY READING	TIME TURBIDITY READ	ENTRY POINT TO DISTRIBUTION					LOWEST RESIDUAL READING	
								12 to 4	4 to 8	8 to 12	12 to 4	4 to 8	8 to 12	
1						.19	1:15P							
2						.21	5:00P							
3						.23	10:30A							
4						.21	5:15P							
5						.24	6:15P							
6						.18	2:40P							
7						.28	8:45P							
8						.21	3:30P							
9						.26	4:30P							
10						.23	3:00P							
11						.16	8:30P							
12						.52	10:15A							
13						.28	4:15P							
14						.21	11:15A							
15						.18	9:30P							
16						.50	10:30A							
17						.25	2:15P							
18						.24	12:15P							
19						.27	11:15A							
20						.32	12:15P							
21						.26	9:15P							
22						.21	7:30A							
23						.29	7:50A							
24						.39	7:50A							
25						.27	12:00P							
26						.24	11:00A							
27						.29	3:00P							
28						.24	3:30P							
29						.21	4:15P							
30						.27	9:00P							
31						.29	9:30P							

Any Time the combined filter effluent turbidity exceeds 5 NTU (>5.49), the state must be notified as soon as possible, but not later than the end of the next business day. ***