

COLORADO DEPARTMENT OF PUBLIC HEALTH AND ENVIRONMENT
MONTHLY OPERATIONAL REPORT - Data Sheet
SLOW SAND, DIATOMACEOUS EARTH & OTHER FILTRATION

Meadow Mountain Water Supply

Required Number of Turbidity Readings Per Day: 1

PWSID #: 00-0207504

DAY	TURBIDITY (NTU)								RESIDUAL DISINFECTANT (mg/L)								12. COMMENTS
	☐ Continuous Sampling ☒ Grab Sampling								☐ Continuous Sampling ☒ Grab Sampling								
	12 to 4	4 to 8	8 to 12	12 to 4	4 to 8	8 to 12	HIGHEST TURBIDITY READING	TIME TURBIDITY READ	12 to 4	4 to 8	8 to 12	12 to 4	4 to 8	8 to 12	LOWEST RESIDUAL READING		
1					1.18		1.18	6:10P						1.0			
2							.67	10:45A							.9		
3							.79	2:30P							.9		
4							.70	7:00P							.8		
5							.62	3:00P							.9		
6							.71	5:00P							.9		
7							.68	4:00P							.9		
8							1.09	10:00A							1.0		
9							.64	11:15A							.9		
10							.72	5:00P							.9		
11							.82	11:00A							.9		
12							.79	3:30P							1.2		
13							.68	4:00P							1.0		
14							.89	3:30P							1.0		
15							.77	10:00A							.9		
16							.63	10:30A							.9		
17							.72	2:15P							.9		
18							.55	2:00P							.8		
19							.56	3:00P							.8		
20							.46	2:30P							1.0		
21							.55	3:30P							1.1		
22							.89	11:25A							.9		
23							.51	10:30A							.9		
24							.88	11:30A							.5		
25							1.13	9:00A							.7		
26							1.17	10:20A							1.1		
27							1.29	3:00P							.5		
28							1.03	3:15P							.9		
29							1.10	10:10A							1.1		
30							.76	10:30A							.7		
31																	

***If at Any Time the combined filter effluent turbidity exceeds 5 NTU (>5.49), the state must be notified as soon as possible, but not later than the end of the next business day. ***