

COLORADO DEPARTMENT OF PUBLIC HEALTH AND ENVIRONMENT

MONTHLY OPERATIONAL REPORT - Data Sheet

SLOW SAND, DIATOMACEOUS EARTH & OTHER FILTRATION

Meadow Mountain
Water Supply
PWSID #: 00207504

Number of Turbidity Readings Per Day: 1

TURBIDITY (NTU)										RESIDUAL DISINFECTANT (mg/L)					RECEIVED	
☐ Continuous Sampling ☒ Grab Sampling										☐ Continuous Sampling ☒ Grab Sampling					SEP 06 2012	
12 to 4	4 to 8	8 to 12	12 to 4	4 to 8	8 to 12	HIGHEST TURBIDITY READING	TIME TURBIDITY READ	ENTRY POINT TO DISTRIBUTION					LOWEST RESIDUAL READING	12. COMMENTS		
12 to 4	4 to 8	8 to 12	12 to 4	4 to 8	8 to 12			12 to 4	4 to 8	8 to 12	12 to 4	4 to 8	8 to 12			
1						.51	3:15P				1.0			1.0		
2						.42	12:16P				1.1			1.1		
3						.37	7:20P					0.9		0.9		
4						.40	4:30P					1.0		1.0		
5						.35	11:40A							1.0		
6						.30	10:30A				1.0			1.0		
7						.38	8:00A				1.0			1.0		
8						.38	3:30P					.8		.8		
9						.24	2:30P					1.0		1.0		
10						.44	2:30P				1.0			1.0		
11						.41	2:30P					1.0		1.0		
12						.34	5:00P					1.0		1.0		
13						.44	11:30A				1.1			1.1		
14						.59	1:30P					1.0		1.0		
15						.44	3:00P					1.0		1.0		
16						.32	2:00P					1.0		1.0		
17						.24	10:45A				1.0			1.0		
18						.74	1:30P					1.1		1.1		
19						.61	7:40P					0.8		0.8		
20						.23	11:45A				1.1			1.1		
21						.27	10:30A				1.0			1.0		
22						.30	3:15P					1.0		1.0		
23						.37	12:45P					1.0		1.0		
24						.38	11:00A				1.1			1.1		
25						.37	9:45A					1.1		1.1		
26						.37	10:15P					1.0		1.0		
27						.41	10:30A				1.0			1.0		
28						.30	7:15P					1.0		1.0		
29						.39	3:00P					7.0		7.0		
30						.47	1:30P					1.0		1.0		
31						.58	3:30P					1.0		1.0		

Any Time the combined filter effluent turbidity exceeds 5 NTU (>5.49), the state must be notified as soon as possible, but not later than the end of the next business day. ***